

**STATE OF NEVADA**  
**PUBLIC WATER SYSTEMS**  
**ANNUAL COMPLIANCE REPORT**  
**FOR**  
**THE YEAR 2006**

**NEVADA DIVISION OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF SAFE DRINKING WATER**  
901 S. STEWART ST., Ste. 4001  
CARSON CITY, NV 89701

## **The Drinking Water Program: An Overview**

The EPA established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs) and the Maximum Residual Disinfectant Levels (MRDLs). For some regulations, EPA establishes treatment techniques in lieu of an MCL to control unacceptable levels of contaminants in water. The Agency also regulates how often public water systems (PWSs) monitor their water for contaminants and report the monitoring results to the states or EPA. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M/R) requirements. In addition, EPA requires PWSs to monitor for unregulated contaminants to provide data for future regulatory development. Finally, EPA requires PWSs to notify their consumers when they have violated these regulations. The 1996 Amendments to the SDWA require consumer notification to include a clear and understandable explanation of the nature of the violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation and the possibility of alternative water supplies during the violation.

The SDWA applies to the 50 states, the District of Columbia, Indian Lands, Puerto Rico, the Virgin Islands, American Samoa, Guam, and the Commonwealth of the Northern Mariana Islands.

The SDWA allows states and territories to seek EPA approval to administer their own PWSS Programs. The authority to run a PWSS Program is called primacy. For a state to receive primacy, EPA must determine that the state meets certain requirements laid out in the SDWA and the regulations, including the adoption of drinking water regulations that are at least as stringent as the Federal regulations and a demonstration that they can enforce the program requirements. Of the 56 states and territories, all but Wyoming and the District of Columbia have primacy. The EPA Regional Offices administer the PWSS Programs within these two jurisdictions.

The 1986 SDWA Amendments gave Indian Tribes the right to apply for and receive primacy. EPA currently administers PWSS Programs on all Indian lands except the Navaho Nation, which was granted primacy in late 2000.

## **Annual State PWS Report**

Each quarter, primacy states submit data to the Safe Drinking Water Information System (SDWIS/FED), an automated database maintained by EPA. The data submitted include, but are not limited to, PWS inventory information, the incidence of Maximum Contaminant Level, Maximum Residual Disinfectant Level, monitoring, and treatment technique violations; and information on enforcement activity related to these violations. Section 1414(c)(3) of the Safe Drinking Water Act requires states to provide EPA with an annual report of violations of the primary drinking water standards. This report provides the numbers of violations in each of six categories: MCLs, MRDLs treatment techniques, variances and exemptions, significant monitoring violations, and significant consumer notification violations. The EPA Regional Offices report the information for Wyoming, the District of Columbia, and all Indian Lands but the Navaho Nation. EPA Regional offices also report Federal enforcement actions taken. Data retrieved from SDWIS/FED form the basis of this report.

### **Public Water System**

A Public Water System (PWS) is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs. PWSs can be community (such as towns), non-transient non-community (such as schools or factories), or transient non-community systems (such as rest stops or parks). For this report when the acronym "PWS" is used, it means systems of all types unless specified in greater detail.

### **Maximum Contaminant Level**

Under the Safe Drinking Water Act (SDWA), the EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs).

### **Maximum Residual Disinfectant Level**

The EPA sets national limits on residual disinfectant levels in drinking water to reduce the risk of exposure to disinfectant byproducts formed, when public water systems add chemical disinfectant for either primary or residual treatment. These limits are known as Maximum Residual Disinfectant Levels (MRDLs).

## **Treatment Techniques**

For some regulations, the EPA establishes treatment techniques (TTs) in lieu of an MCL to control unacceptable levels of certain contaminants. For example, treatment techniques have been established for viruses, some bacteria, and turbidity.

## **Variances and Exemptions**

A primacy state can grant a PWS a variance from a primary drinking water regulation if the characteristics of the raw water sources reasonably available to the PWS do not allow the system to meet the MCL. To obtain a variance, the system must agree to install the best available technology, treatment techniques, or other means of limiting drinking water contamination that the Administrator finds are available (taking costs into account), and the state must find that the variance will not result in an unreasonable risk to public health. The variance shall be reviewed not less than every 5 years to determine if the system remains eligible for the variance.

A primacy state can grant an exemption temporarily relieving a PWS of its obligation to comply with an MCL, treatment technique, or both if the system's noncompliance results from compelling factors (which may include economic factors) and the system was in operation on the effective date of the MCL or treatment technique requirement. The state will require the PWS to comply with the MCL or treatment technique as expeditiously as practicable, but not later than 3 years after the otherwise applicable compliance date.

## **Monitoring**

A PWS is required to monitor and verify that the levels of contaminants present in the water do not exceed the MCL. If a PWS fails to have its water tested as required or fails to report test results correctly to the primacy agent, a monitoring violation occurs.

## **Significant Monitoring Violations**

For this report, significant monitoring violations are generally defined as any Significant monitoring violation that occurred during the calendar year of the report. A Significant monitoring violation, with rare exceptions, occurs when no samples were taken or no results were reported during a compliance period.

### **Consumer Notification**

Every Community Water System is required to deliver to its customers a brief annual water quality report. This report is to include some educational material, and will provide information on the source water, the levels of any detected contaminants, and compliance with drinking water regulations.

### **Significant Consumer Notification Violations**

For this report, a significant public notification violation occurred if a community water system completely failed to provide its customers the required annual water quality report.

NEVADA PUBLIC WATER SYSTEMS  
GENERAL INFORMATION

There are **581 Active Public Water Systems in Nevada:**

**228 Community Systems** serving 2,417,311 people.

193 systems serve between 25 and 3,300 people.

22 systems serve between 3,301 and 10,000 people.

8 systems serve between 10,001 and 50,000 people.

5 systems serve more than 50,000 people.

30 of the Community Water Systems use surface water and serve 2,175,402 of the 2,417,311 people that are served by Community water systems.

**107 Non-Transient Non-Community Systems (NTNC)** serving 43,622 people.

105 systems serve between 25 and 3,300 people.

2 systems serve between 3,301 and 10,000 people.

5 of the Non-Transient Non-Community Systems use surface water and serve 9,545 of the 43,622 served by NTNC systems.

**246 Transient Non-Community Systems (NC)** serving 25,025 people.

All of the Transient Non-Community Systems serve between 25 and 3,300 people.

2 of the Transient Non-Community Systems use surface water and serve 425 of the 25,025 people served by NC systems.

## Where to Obtain the 2006 Annual State Public Water Systems Report

NEVADA publishes their ACR and distributes them to the county libraries in the state.

## 2006 VIOLATION STATISTICS FOR NEVADA WATER SYSTEMS

Total Number of Regulated Systems	581
Total Number of Systems in Violation	226
Total Number of Violations	841

State of Nevada 2006 PWS Compliance Report  
Violations for 2006

Violations Category	Systems in Violation	Violations
Maximum Contaminant Level Excedence violations	10	21
Treatment Technique Significant Monitoring Violations	0	0
Chemical Contaminant Group Monitoring Violations	70	443
Total Coliform Rule	150	206
Surface Water Treatment Rule, Interim Enhanced Surface Water	2	2
Treatment Rule and Filter Backwash Recycling Rule	0	0
Lead and Copper Rule	8	9
Consumer Confidence Report	53	53
Disinfection Byproducts Rule	24	100

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
CLARK	COMMUNITY	NV0000151	AAA MOBILE HOME RENTAL	75	GROUNDWATER	1	WELL(S)		
LINCOLN	COMMUNITY	NV0000005	ALAMO SEWER AND WATER GID	900	GROUNDWATER	4	WELL(S)		
NYE	COMMUNITY	NV0002558	AMARGOSA VALLEY WATER ASSOCIATION	25	GROUNDWATER	2	WELL(S)		
NYE	COMMUNITY	NV0005033	ANCHOR INN MHP	36	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000901	ARROWCREEK	1,975	GROUNDWATER	5	WELL(S)		
WASHOE	COMMUNITY	NV0000191	ARROWHEAD MHP	65	GROUNDWATER	2	WELL(S)		
WHITE PINE	COMMUNITY	NV0000863	BAKER WATER AND SEWER GID	85	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0000009	BEATTY WATER AND SANITATION DISTRICT	1,100	GROUNDWATER	3	WELL(S)		
CLARK	COMMUNITY	NV0004092	BIG BEND WATER DISTRICT	8,300	SURFACE WATER	1	INTAKE(S)		
NYE	COMMUNITY	NV0000362	BIG FIVE PARK	65	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0000369	BIG VALLEY MHP	50	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000092	BLUE DIAMOND WATER CO OP INC	25	GROUNDWATER	1	SPRING(S)		
CLARK	COMMUNITY	NV0000010	BLUE DIAMOND WATER COMPANY	310	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000011	BOULDER CITY	15,000	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
NYE	COMMUNITY	NV0002538	C VALLEY MHP	54	GROUNDWATER	2	WELL(S)		
LINCOLN	COMMUNITY	NV0000013	CALIENTE PUBLIC UTILITIES	1,500	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0002589	CALVADA NORTH UICN	100	GROUNDWATER	1	WELL(S)		
STOREY	COMMUNITY	NV0005056	CANYON GID	2,370	GROUNDWATER	2	WELL(S)		
ELKO	COMMUNITY	NV0000014	CARLIN UTILITIES	2,450	GROUNDWATER	1	SPRING(S)		1 WELL(S)
CARSON CITY	COMMUNITY	NV0000015	CARSON CITY PUBLIC WORKS	56,500	SURFACE WATER	3	INTAKE(S)		29 WELL(S)
CHURCHILL	COMMUNITY	NV0003068	CARSON RIVER ESTATES	90	GROUNDWATER	3	WELL(S)		
NYE	COMMUNITY	NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	180	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0000259	CAVE ROCK SKYLAND	1,245	SURFACE WATER	1	INTAKE(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
LYON	COMMUNITY	NV0000813	CHURCHILL RANCHOS ESTATES	172	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000102	CITY VUE MHP	75	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0004000	COLD CREEK CANYON HOMEOWNERS	180	GROUNDWATER	2	WELL(S)		
WHITE PINE	COMMUNITY	NV0005057	COLD CREEK MHP	35	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000277	CONESTOGA MHP	120	GROUNDWATER	1	WELL(S)		
CARSON CITY	COMMUNITY	NV0000017	COTTONWOOD MHP	250	GROUNDWATER	3	WELL(S)		
CHURCHILL	COMMUNITY	NV0000046	COUNTRY CLUB ESTATES	130	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0005032	COUNTRY VIEW ESTATES UICN	372	GROUNDWATER	2	WELL(S)		
EUREKA	COMMUNITY	NV0000043	CRESCENT VALLEY WATER SYSTEM	350	GROUNDWATER	2	WELL(S)		
LYON	COMMUNITY	NV0000361	CRYSTAL CLEAR WATER COMPANY	400	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0000193	CRYSTAL TP	80	GROUNDWATER	2	WELL(S)		
LYON	COMMUNITY	NV0000033	DAYTON VALLEY MHP	55	GROUNDWATER	2	WELL(S)		
LYON	COMMUNITY	NV0000032	DAYTON VALLEY WATER SYSTEM	12,035	GROUNDWATER	15	WELL(S)		
CHURCHILL	COMMUNITY	NV0000047	DELUXE MHP	37	GROUNDWATER	2	WELL(S)		
NYE	COMMUNITY	NV0000831	DESERT MIRAGE HOMEOWNERS ASSOCIATION	230	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000149	DESERT PARADISE MHP	70	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0001085	DESERT SPRINGS UTILITY COMPANY	7,629	PURCHASED SURFACE WATER	2	CONSECUTIVE CONNECTIONS	4	WELL(S)
NYE	COMMUNITY	NV0000300	DESERT UTILITIES	625	GROUNDWATER	2	WELL(S)		
EUREKA	COMMUNITY	NV0002574	DEVILS GATE GID DISTRICT 1	25	GROUNDWATER	2	WELL(S)		
EUREKA	COMMUNITY	NV0002573	DEVILS GATE WATER SYSTEM GID 2	70	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000832	DOUBLE DIAMOND	12,907	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION	1	WELL(S)
PERSHING	COMMUNITY	NV0000809	DUTCHMAN ACRES	121	GROUNDWATER	2	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
DOUGLAS	COMMUNITY	NV0002216	EAST VALLEY WATER SYSTEM	3,845	GROUNDWATER	3	WELL(S)		
CLARK	COMMUNITY	NV0000106	EASTLAND HEIGHTS WATER ASSOCIATION	500	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0000271	ELK POINT COUNTRY CLUB	325	GROUNDWATER	2	WELL(S)		
ELKO	COMMUNITY	NV0000272	ELKO CITY OF	18,000	GROUNDWATER	17	WELL(S)		
WHITE PINE	COMMUNITY	NV0005071	ELY MAXIMUM SECURITY PRISON NDOP	1,030	GROUNDWATER	2	WELL(S)		
WHITE PINE	COMMUNITY	NV0000038	ELY MUNICIPAL WATER DEPARTMENT	6,000	GROUNDWATER	1	SPRING(S)	2	WELL(S)
CHURCHILL	COMMUNITY	NV0004002	EM BER MOBILE MANOR	35	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000042	EMPIRE WATER COMPANY	350	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	108	GROUNDWATER	2	WELL(S)		
NYE	COMMUNITY	NV0002552	ESCAPEE CO OP OF NEVADA	200	GROUNDWATER	2	WELL(S)		
EUREKA	COMMUNITY	NV0000044	EUREKA WATER ASSOCIATION	527	GROUNDWATER	5	SPRING(S)	2	WELL(S)
HUMBOLDT	COMMUNITY	NV0000249	F AND H TP	66	GROUNDWATER	1	WELL(S)		
CHURCHILL	COMMUNITY	NV0000045	FALLON CITY OF	8,500	GROUNDWATER	1	CONSECUTIVE CONNECTION		
CHURCHILL	COMMUNITY	NV0000045	FALLON CITY OF	8,500	GROUNDWATER	4	WELL(S)		
CHURCHILL	COMMUNITY	NV0000350	FALLON NAVAL AIR STATION	3,000	GROUNDWATER	1	CONSECUTIVE CONNECTION		
CHURCHILL	COMMUNITY	NV0000350	FALLON NAVAL AIR STATION	3,000	GROUNDWATER	3	WELL(S)		
LYON	COMMUNITY	NV0000062	FERNLEY PUBLIC WORKS	14,000	GROUNDWATER	6	WELL(S)		
LYON	COMMUNITY	NV0002516	FIVE STAR MHP	90	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000200	FOOTHILL TRAILER PARK	35	GROUNDWATER	1	WELL(S)		
DOUGLAS	COMMUNITY	NV0000959	FOOTHILL WATER SYSTEM	346	GROUNDWATER	4	WELL(S)		
CARSON CITY	COMMUNITY	NV0000020	FRONTIER VILLAGE MHP CC	280	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0000147	FRONTIER VILLAGE MHP CL	60	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0000063	GABBS WATER SYSTEM	411	GROUNDWATER	1	WELL(S)		
DOUGLAS	COMMUNITY	NV0000066	GARDNERVILLE RANCHOS GID	11,500	GROUNDWATER	6	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
DOUGLAS	COMMUNITY	NV0000065	GARDNERVILLE TOWN WATER	4,500	GROUNDWATER	7	WELL(S)		
WASHOE	COMMUNITY	NV0000071	GERLACH GID	180	GROUNDWATER	2	SPRING(S)		
DOUGLAS	COMMUNITY	NV0000356	GLENBROOK HOMEOWNERS ASSOCIATION	1,000	SURFACE WATER	1	INTAKE(S)		
HUMBOLDT	COMMUNITY	NV0005029	GOLCONDA GID	219	GROUNDWATER	1	SPRING(S)	2	WELL(S)
HUMBOLDT	COMMUNITY	NV0003079	GOLD COUNTRY ESTATES	950	GROUNDWATER	2	WELL(S)		
ESMERALDA	COMMUNITY	NV0000072	GOLDFIELD TOWN WATER	500	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0000035	GRAND VIEW TERRACE WATER DISTRICT	328	GROUNDWATER	3	WELL(S)		
NYE	COMMUNITY	NV0004074	HADLEY SUBDIVISION	1,200	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0001080	HARRIS SPRINGS RANCH	40	GROUNDWATER	1	WELL(S)		
MINERAL	COMMUNITY	NV0000357	HAWTHORNE ARMY AMMO DEPOT	300	SURFACE WATER	1	INTAKE(S)	2	WELL(S)
MINERAL	COMMUNITY	NV0000073	HAWTHORNE UTILITIES	3,013	GROUNDWATER	5	WELL(S)		
CLARK	COMMUNITY	NV0000076	HENDERSON CITY OF	246,000	SURFACE WATER	2	CONSECUTIVE CONNECTIONS	1	INTAKE
WASHOE	COMMUNITY	NV0000198	HIDDEN VALLEY	4,140	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION	3	WELL(S)
CLARK	COMMUNITY	NV0000145	HILLCREST MANOR WATER USERS ASSOCIATION	450	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000146	HITCHIN POST MOTEL AND RV PARK	350	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0002046	HOLBROOK STATION RV AND MHP	180	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000729	HORIZON HILLS GID WCUD	370	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
PERSHING	COMMUNITY	NV0000226	IMLAY WATER SYSTEM	200	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000158	INCLINE VILLAGE GID	9,313	SURFACE WATER	1	INTAKE(S)		
DOUGLAS	COMMUNITY	NV0000355	INDIAN HILLS GID	5,800	GROUNDWATER	7	WELL(S)		
CLARK	COMMUNITY	NV0000082	INDIAN SPRINGS WATER CO INC	900	GROUNDWATER	2	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
ELKO	COMMUNITY	NV0000088	JACKPOT WATER SYSTEM	1,240	GROUNDWATER	4	WELL(S)		
ELKO	COMMUNITY	NV0002070	JARBIDGE WATER SYSTEM	200	SURFACE WATER	1	INTAKE(S)		
CLARK	COMMUNITY	NV0000089	JEAN UTILITY SERVICES INC	600	GROUNDWATER	3	WELL(S)		
WASHOE	COMMUNITY	NV0000199	KE TA MOBILE HOME PARK	60	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000287	KINGS ROW TP	525	GROUNDWATER	1	WELL(S)		
DOUGLAS	COMMUNITY	NV0000004	KINGSBURY GID	3,839	SURFACE WATER	1	INTAKE(S)		
LANDER	COMMUNITY	NV0000265	KINGSTON TOWN WATER UTILITIES	275	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000142	KYLE CANYON WATER DISTRICT	1,040	GROUNDWATER	4	WELL(S)		
CLARK	COMMUNITY	NV0004090	LALLYS	51	GROUNDWATER	1	WELL(S)		
ELKO	COMMUNITY	NV0000273	LAMOILLE WATER USERS ASSOC	200	GROUNDWATER	1	WELL(S)		
LANDER	COMMUNITY	NV0000008	LANDER CO SEWER AND WATER DIST 1 BM	4,600	GROUNDWATER	3	WELL(S)		
LANDER	COMMUNITY	NV0000006	LANDER CO SEWER AND WATER DIST 2 AUSTIN	350	GROUNDWATER	2	SPRING(S)	2	WELL(S)
CLARK	COMMUNITY	NV0000090	LAS VEGAS VALLEY WATER DISTRICT	1,181,263	PURCHASED SURFACE WATER	2	CONSECUTIVE CONNECTIONS	61	WELL(S)
WASHOE	COMMUNITY	NV0000202	LEMMON VALLEY WATER COMPANY	2,853	GROUNDWATER	4	WELL(S)		
WASHOE	COMMUNITY	NV0000865	LIGHTNING W WCUD	90	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0002050	LOGAN CREEK ESTATES GID	60	GROUNDWATER	1	WELL(S)		
PERSHING	COMMUNITY	NV0000861	LOVELOCK CORRECTIONAL CENTER NDOP	1,550	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
PERSHING	COMMUNITY	NV0000161	LOVELOCK MEADOWS WATER DISTRICT	3,900	GROUNDWATER	2	WELL(S)		
NYE	COMMUNITY	NV0000165	MANHATTAN TOWN WATER	40	GROUNDWATER	1	WELL(S)		
HUMBOLDT	COMMUNITY	NV0000162	MCDERMITT WATER SYSTEM	200	GROUNDWATER	2	WELL(S)		
WHITE PINE	COMMUNITY	NV0000163	MCGILL WATER AND SEWER DIST	1,200	GROUNDWATER	2	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
MINERAL	COMMUNITY	NV0000074	MINA LUNING WATER SYSTEM	391	GROUNDWATER	3	WELL(S)		
CLARK	COMMUNITY	NV0000160	MOAPA VALLEY WATER DISTRICT	8,000	GROUNDWATER	2	SPRING(S)	3	WELL(S)
ELKO	COMMUNITY	NV0000169	MONTELOLO WATER SYSTEM	287	GROUNDWATER	2	SPRING(S)		
WASHOE	COMMUNITY	NV0000732	MOUNT ROSE BOWL HOMEOWNERS ASSOCIATION	40	GROUNDWATER	1	SPRING(S)	1	WELL(S)
WASHOE	COMMUNITY	NV0003030	MOUNT ROSE WATER COMPANY	1,650	GROUNDWATER	4	WELL(S)		
ELKO	COMMUNITY	NV0000170	MOUNTAIN CITY WATER SYSTEM	30	GROUNDWATER	1	SPRING(S)		
NYE	COMMUNITY	NV0000920	MOUNTAIN FALLS WATER SYSTEM UICN	390	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0003081	MOUNTAIN VIEW MHP	45	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0005067	MOUNTAIN VIEW MHP UICN	50	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0001015	MT CHARLESTON WATER COMPANY	535	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0003028	NELLIS AIR FORCE BASE	6,288	PURCHASED SURFACE WATER	2	CONSECUTIVE CONNECTIONS	5	WELL(S)
ELKO	COMMUNITY	NV0000037	NEVADA YOUTH TRAINING CENTER	100	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000175	NORTH LAS VEGAS UTILITIES	270,653	PURCHASED SURFACE WATER	2	CONSECUTIVE CONNECTIONS	5	WELL(S)
CLARK	COMMUNITY	NV0003005	NPS BOULDER BEACH	722	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
CLARK	COMMUNITY	NV0002506	NPS CALLVILLE BAY	250	SURFACE WATER	1	INTAKE(S)		
CLARK	COMMUNITY	NV0002501	NPS COTTONWOOD COVE	1,354	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0002503	NPS ECHO BAY	237	SURFACE WATER	1	INTAKE(S)		
CLARK	COMMUNITY	NV0003003	NPS OVERTON BEACH	250	SURFACE WATER	1	INTAKE(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
CLARK	COMMUNITY	NV0000140	OAKRIDGE APARTMENTS	126	GROUNDWATER	1	WELL(S)		
ELKO	COMMUNITY	NV0004017	OASIS INT MHP	46	GROUNDWATER	1	WELL(S)		
CHURCHILL	COMMUNITY	NV0000051	OASIS MHP	100	GROUNDWATER	3	WELL(S)		
CHURCHILL	COMMUNITY	NV0000052	OK MOBILE HOME PARK	90	GROUNDWATER	1	WELL(S)		
CHURCHILL	COMMUNITY	NV0000303	OLD RIVER WATER COMPANY	300	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0002526	OLD WASHOE ESTATES WCUD	128	GROUNDWATER	2	WELL(S)		
HUMBOLDT	COMMUNITY	NV0003032	OROVADA WATER DISTRICT	200	GROUNDWATER	2	WELL(S)		
NYE	COMMUNITY	NV0000183	PAHRUMP MHP	75	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0000926	PAHRUMP UTILITY COMPANY INC	300	GROUNDWATER	3	WELL(S)		
CLARK	COMMUNITY	NV0000132	PAINTED DESERT WTR USERS ASSOC	52	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0000819	PALM GARDENS WATER CO OP	60	GROUNDWATER	2	WELL(S)		
LINCOLN	COMMUNITY	NV0000185	PANACA FARMSTEAD WATER ASSOCIATION	800	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000205	PANTHER VALLEY WATER COMPANY	1,800	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
CHURCHILL	COMMUNITY	NV0000849	PINE GROVE UTILITY TRUST	25	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0000067	PINION PINES MHP	45	GROUNDWATER	1	WELL(S)		
LINCOLN	COMMUNITY	NV0000186	PIOCHE PUBLIC UTILITIES	781	GROUNDWATER	3	WELL(S)		
LINCOLN	COMMUNITY	NV0000187	PIOCHE PUBLIC UTILITIES CASTLETON	60	GROUNDWATER	1	SPRING(S)		
WASHOE	COMMUNITY	NV0000206	PIONEER HILLS MHP	427	GROUNDWATER	2	WELL(S)		
NYE	COMMUNITY	NV0000402	PLEASANT VALLEY	97	GROUNDWATER	3	WELL(S)		
CHURCHILL	COMMUNITY	NV0000054	R AND M MOBILE HOME PARK	130	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000370	RAINBOW GARDENS WATER USERS	45	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0000129	RANCHO COOPERATIVE WATER COMPANY	110	GROUNDWATER	2	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
WASHOE	COMMUNITY	NV0000701	RENO SAHARA TRAILER PARK	60	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000754	RIVER BEND MHP	90	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000244	RIVERBELLE PROPERTIES LLC MHP	150	GROUNDWATER	1	SPRING(S)		
DOUGLAS	COMMUNITY	NV0000068	RIVERVIEW MOBILE HOME PARK	59	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0000319	ROARK ESTATES WATER ASSOC	62	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000767	ROSEMOUNT WATER CO	54	GROUNDWATER	1	SPRING(S)		
DOUGLAS	COMMUNITY	NV0000260	ROUND HILL GID	1,200	SURFACE WATER	1	INTAKE(S)		
WHITE PINE	COMMUNITY	NV0000164	RUTH WATER DISTRICT	700	GROUNDWATER	2	SPRING(S)		
WASHOE	COMMUNITY	NV0000231	SAGE TRAILER PARK	32	GROUNDWATER	1	WELL(S)		
CHURCHILL	COMMUNITY	NV00002023	SAGE VALLEY MHP	158	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0000219	SEARCHLIGHT WATER COMPANY	760	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000126	SHETLAND WATER DISTRICT	45	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0005028	SHOSHONE ESTATES WATER COMPANY	240	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0000931	SIERRA COUNTRY ESTATES	38	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0000030	SIERRA ESTATES GID	160	GROUNDWATER	1	WELL(S)		
DOUGLAS	COMMUNITY	NV0002054	SIERRA SHADOWS GENOA LAKES	663	GROUNDWATER	4	WELL(S)		
WASHOE	COMMUNITY	NV0004021	SILVER KNOLLS MUTUAL WATER COMPANY	120	GROUNDWATER	2	WELL(S)		
ESMERALDA	COMMUNITY	NV0000363	SILVER PEAK WATER SYSTEM	138	GROUNDWATER	2	WELL(S)		
LYON	COMMUNITY	NV0000267	SILVER SPRINGS MHP	70	GROUNDWATER	1	WELL(S)		
LYON	COMMUNITY	NV0000223	SILVER SPRINGS MUTUAL WATER COMPANY	3,000	GROUNDWATER	4	WELL(S)		
CLARK	COMMUNITY	NV0004031	SKY RANCH ESTATES	160	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0001086	SKY RANCH WATER SERVICE CORPORATION	2,030	GROUNDWATER	2	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
ELKO	COMMUNITY	NV0000351	SOUTH CRESTVIEW HOMEOWNERS	60	GROUNDWATER	3	WELL(S)		
CHURCHILL	COMMUNITY	NV0000055	SOUTH MAINE MHP	100	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0000215	SOUTH TRUCKEE MEADOWS GID	8,307	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION	8	WELL(S)
CLARK	COMMUNITY	NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOP	4,142	GROUNDWATER	4	WELL(S)		
CLARK	COMMUNITY	NV0000221	SPIRIT MOUNTAIN UTILITY	350	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0000800	SPRING CREEK EAST COUNTRYSIDE	1,164	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
WASHOE	COMMUNITY	NV0000800	SPRING CREEK EAST COUNTRYSIDE	1,164	PURCHASED SURFACE WATER	4	WELL(S)		
ELKO	COMMUNITY	NV0005027	SPRING CREEK MHP	4,146	GROUNDWATER	3	WELL(S)		
ELKO	COMMUNITY	NV0000036	SPRING CREEK UTILITIES	6,792	GROUNDWATER	8	WELL(S)		
WASHOE	COMMUNITY	NV0004082	SPRING CREEK WATER COMPANY	1,850	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION	1	WELL(S)
CLARK	COMMUNITY	NV0000292	SPRING MOUNTAIN YOUTH CAMP	180	GROUNDWATER	1	SPRING(S)		
WASHOE	COMMUNITY	NV0000900	ST JAMES	200	GROUNDWATER	2	WELL(S)		
LYON	COMMUNITY	NV0000224	STAGECOACH GID	1,059	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0000801	STAMPMILL	110	GROUNDWATER	2	WELL(S)		
HUMBOLDT	COMMUNITY	NV0000252	STAR CITY PROPERTIES	500	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	998	GROUNDWATER	2	WELL(S)		
STOREY	COMMUNITY	NV0000240	STOREY COUNTY WATER DISTRICT	600	SURFACE WATER	1	INTAKE(S)		
WASHOE	COMMUNITY	NV0000211	SUN VALLEY GID	17,000	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
CLARK	COMMUNITY	NV0000124	SUNRISE ACRES WATER ASSOCIATION	231	GROUNDWATER	2	WELL(S)		
DOUGLAS	COMMUNITY	NV0000887	SUNRISE ESTATES	91	GROUNDWATER	2	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
WASHOE	COMMUNITY	NV0002525	SUNRISE ESTATES WATER SYSTEM	86	GROUNDWATER	3	WELL(S)		
CLARK	COMMUNITY	NV0000123	SUNRISE MOUNTAIN TP	100	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0005066	SUNSET MHP	90	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0000765	SUTCLIFFE MOBILE PARK	60	GROUNDWATER	2	WELL(S)		
CARSON CITY	COMMUNITY	NV0000028	TERRACE GARDEN APARTMENTS	60	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000792	THOMAS CREEK ESTATES WATER COMPANY	498	GROUNDWATER	1	WELL(S)		
WASHOE	COMMUNITY	NV0000214	THREE T WATER COMPANY	92	GROUNDWATER UNDER INFLUENCE OF SURFACE WATER	1	SPRING(S)		
WASHOE	COMMUNITY	NV0000802	TIMBERLINE ESTATES	75	GROUNDWATER	1	WELL(S)		
CHURCHILL	COMMUNITY	NV0000061	TOLAS PARK MHP	54	GROUNDWATER	1	WELL(S)		
NYE	COMMUNITY	NV0000237	TONOPAH PUBLIC UTILITIES	2,600	GROUNDWATER	8	WELL(S)		
DOUGLAS	COMMUNITY	NV0000070	TOPAZ LODGE WATER CO INC	40	GROUNDWATER	3	WELL(S)		
DOUGLAS	COMMUNITY	NV0000239	TOPAZ RANCH ESTATES GID	2,100	GROUNDWATER	4	WELL(S)		
CLARK	COMMUNITY	NV0000314	TORREY PINES TINA LN WTR ASSOC	70	GROUNDWATER	1	WELL(S)		
DOUGLAS	COMMUNITY	NV0000168	TOWN OF MINDEN	3,200	GROUNDWATER	6	WELL(S)		
WASHOE	COMMUNITY	NV0000190	TRUCKEE MEADOWS WATER AUTHORITY	315,200	SURFACE WATER	2	INTAKE(S)	31	WELL(S)
ELKO	COMMUNITY	NV0000189	TUSCARORA WATER SYSTEM	72	GROUNDWATER	1	WELL(S)		
DOUGLAS	COMMUNITY	NV0000817	UPPAWAY WATER SYSTEM	85	GROUNDWATER	2	WELL(S)		
NYE	COMMUNITY	NV0000270	UTILITIES INC OF CENTRAL NEVADA	6,960	GROUNDWATER	5	WELL(S)		
WASHOE	COMMUNITY	NV0000207	UTILITIES INC OF NEVADA	7,962	GROUNDWATER	5	WELL(S)		
ELKO	COMMUNITY	NV0000805	VALLEY VIEW RV PARK	250	GROUNDWATER	2	WELL(S)		
HUMBOLDT	COMMUNITY	NV0003016	VALMY STATION MOBILE HOME PARK	60	GROUNDWATER	1	WELL(S)		
CLARK	COMMUNITY	NV0000182	VANS TRAILER OASIS	75	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
WASHOE	COMMUNITY	NV0000196	VERDI MEADOWS UTILITY COMPANY INC	510	GROUNDWATER	2	WELL(S)		
CLARK	COMMUNITY	NV0000167	VIRGIN VALLEY WATER DISTRICT	17,000	GROUNDWATER	9	WELL(S)		
WASHOE	COMMUNITY	NV0000281	WADSWORTH MOBILE HOME PARK	75	GROUNDWATER	2	WELL(S)		
MINERAL	COMMUNITY	NV0000302	WALKER LAKE APARTMENTS	50	GROUNDWATER	1	WELL(S)		
MINERAL	COMMUNITY	NV0000268	WALKER LAKE GID	525	GROUNDWATER	2	WELL(S)		
WASHOE	COMMUNITY	NV0000280	WEBB MOBILE HOME PARK	80	GROUNDWATER	2	WELL(S)		
LYON	COMMUNITY	NV0000242	WEED HEIGHTS DEVELOPMENT	500	GROUNDWATER	2	WELL(S)		
ELKO	COMMUNITY	NV0000245	WELLS MUNICIPAL WATER DEPARTMENT	1,346	GROUNDWATER	4	WELL(S)		
CHURCHILL	COMMUNITY	NV0000060	WEST STAR MHP	35	GROUNDWATER	1	WELL(S)		
DOUGLAS	COMMUNITY	NV0002564	WEST VALLEY/ MONTANA/ MTN MEADOW ESTATES	30	GROUNDWATER	2	WELL(S)		
ELKO	COMMUNITY	NV0000246	WEST WENDOVER WATER SYSTEM	4,200	GROUNDWATER	1	SPRING(S)	3	WELL(S)
CLARK	COMMUNITY	NV0001073	WHISKEY PETES	3,000	GROUNDWATER	2	WELL(S)		
CHURCHILL	COMMUNITY	NV0000058	WILDES MANOR	70	GROUNDWATER	1	WELL(S)		
HUMBOLDT	COMMUNITY	NV0000248	WINNEMUCCA CITY OF	8,643	GROUNDWATER	1	SPRING(S)	4	WELL(S)
LYON	COMMUNITY	NV0000255	YERINGTON CITY OF	2,900	GROUNDWATER	5	WELL(S)		
DOUGLAS	COMMUNITY	NV0000258	ZEPHYR COVE WATER UTILITY DISTR	1,875	SURFACE WATER	1	INTAKE(S)		
STOREY	NON-TRANSIENT NON-COMMUNITY	NV0000879	ALCOA MICROMILL	31	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0002190	AMARGOSA ELEMENTARY SCHOOL	200	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0003061	AMARGOSA SENIOR CENTER	25	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0005037	AMARGOSA TOWN COMPLEX	25	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0000379	APEX REGIONAL WASTE MGMT CENTER	107	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0000087	BARRICK GOLDSTRIKE ADMINISTRATION	30	GROUNDWATER	1	WELL(S)		
EUREKA	NON-TRANSIENT NON-COMMUNITY	NV0005077	BARRICK GOLDSTRIKE FACILITY	2,100	GROUNDWATER	2	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0001001	BONNIE SPRINGS OLD NEVADA	500	GROUNDWATER	1	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000709	BOOMTOWN HOTEL AND CASINO INC	200	GROUNDWATER	5	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0000364	BPB GYPSUM INC	85	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000896	BRISTLECONE FAMILY RESOURCES	25	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0002524	CARLIN HONOR CAMP NDOP	147	GROUNDWATER	1	WELL(S)		
CARSON CITY	NON-TRANSIENT NON-COMMUNITY	NV0000958	CARSON CITY TOYOTA	30	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0001000	CHEMICAL LIME COMPANY	52	GROUNDWATER	2	WELL(S)		
DOUGLAS	NON-TRANSIENT NON-COMMUNITY	NV0005078	CHINA SPRINGS YOUTH CAMP	92	GROUNDWATER	1	WELL(S)		
CHURCHILL	NON-TRANSIENT NON-COMMUNITY	NV0000903	CMC STEEL FABRICATORS DBA CMC JOIST	400	GROUNDWATER	1	WELL(S)		
PERSHING	NON-TRANSIENT NON-COMMUNITY	NV0003076	COEUR ROCHESTER INC	240	GROUNDWATER	2	WELL(S)		
LANDER	NON-TRANSIENT NON-COMMUNITY	NV0000892	CORTEZ GOLD MINES PIPELINE	400	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0001081	CREECH AIR FORCE BASE	300	GROUNDWATER	2	WELL(S)		
HUMBOLDT	NON-TRANSIENT NON-COMMUNITY	NV0000864	CROFOOT MINE HYCROFT RESOURCES	25	GROUNDWATER	1	WELL(S)		
ESMERALDA	NON-TRANSIENT NON-COMMUNITY	NV0002184	DYER ELEMENTARY SCHOOL	60	GROUNDWATER	2	WELL(S)		
STOREY	NON-TRANSIENT NON-COMMUNITY	NV0003075	EAGLE PICHER MINERALS	50	GROUNDWATER	1	WELL(S)		
DOUGLAS	NON-TRANSIENT NON-COMMUNITY	NV0000235	EDGEWOOD WATER COMPANY	5,695	SURFACE WATER	1	INTAKE(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
WHITE PINE	NON-TRANSIENT NON-COMMUNITY	NV0004083	ELY CONSERVATION CAMP NDOP	150	GROUNDWATER	1	WELL(S)		
PERSHING	NON-TRANSIENT NON-COMMUNITY	NV0000884	FLORIDA CANYON MINING INC	100	GROUNDWATER	1	WELL(S)		
LYON	NON-TRANSIENT NON-COMMUNITY	NV0000806	FORT CHURCHILL POWER PLANT	37	GROUNDWATER	2	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0000327	GAYE HAVEN CARE HOME	50	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0000372	GEORGIA PACIFIC GYPSUM LLC	100	GROUNDWATER	1	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000751	GOLD RANCH CASINO	1,000	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0001045	GOODSPRINGS SCHOOL	25	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0001083	HACIENDA HOTEL AND CASINO	250	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
LYON	NON-TRANSIENT NON-COMMUNITY	NV0004053	HODGES TRANSPORTATION CO	160	GROUNDWATER	3	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0000349	HOLLISTER HECLA WATER SYSTEM	30	GROUNDWATER	1	WELL(S)		
EUREKA	NON-TRANSIENT NON-COMMUNITY	NV0000885	HOMESTAKE MINE RUBY HILL	90	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0003006	HOOVER DAM	3,000	SURFACE WATER	2	INTAKE(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0004067	HORIZON ACADEMY	50	GROUNDWATER	1	WELL(S)		
HUMBOLDT	NON-TRANSIENT NON-COMMUNITY	NV0005069	HUMBOLDT CONSERVATION CAMP NDOP	140	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0005006	INDIAN SPGS AIR FORCE PT BRAVO	50	GROUNDWATER	1	WELL(S)		
CHURCHILL	NON-TRANSIENT NON-COMMUNITY	NV0000906	JETWAY CHEVROLET	40	GROUNDWATER	1	WELL(S)		
CHURCHILL	NON-TRANSIENT NON-COMMUNITY	NV0002024	KENNAMETAL INC	75	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0000932	KEYSTONE ACADEMY	30	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0000928	LAMOILLE VALLEY PLAZA	25	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0005068	LDS CHURCH PAHRUMP WARD	25	GROUNDWATER	1	WELL(S)		
EUREKA	NON-TRANSIENT NON-COMMUNITY	NV0000338	LEEVILLE POTABLE WATER SYSTEM	147	GROUNDWATER	2	WELL(S)		
HUMBOLDT	NON-TRANSIENT NON-COMMUNITY	NV0000907	LONE TREE MINE	150	GROUNDWATER	2	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0000871	LONGSTREET INN AND CASINO	25	GROUNDWATER	2	WELL(S)		
WHITE PINE	NON-TRANSIENT NON-COMMUNITY	NV0000979	LUND SCHOOL	140	GROUNDWATER	1	WELL(S)		
STOREY	NON-TRANSIENT NON-COMMUNITY	NV0000878	MARS PETCARE US INC	140	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0001048	MOHAVE GENERATING STATION	400	SURFACE WATER	1	INTAKE(S)		
CHURCHILL	NON-TRANSIENT NON-COMMUNITY	NV0002541	NAS CENTROID EW RANGE	80	GROUNDWATER	1	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000869	NATCHEZ GYM	175	GROUNDWATER	1	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000774	NATCHEZ SCHOOL	200	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0000360	NEVADA TEST SITE A23 AND 6	1,700	GROUNDWATER	3	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0004098	NEVADA TEST SITE AREA 25	100	GROUNDWATER	2	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000874	NEW BEGINNINGS CHRISTIAN CHURCH	25	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0004072	NEW FRONTIER HOTEL	1,300	GROUNDWATER	1	WELL(S)		
EUREKA	NON-TRANSIENT NON-COMMUNITY	NV0002600	NEWMONT GOLD GOLD QUARRY	700	GROUNDWATER	2	WELL(S)		
EUREKA	NON-TRANSIENT NON-COMMUNITY	NV0002092	NEWMONT GOLD MILL 1	100	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
EUREKA	NON-TRANSIENT NON-COMMUNITY	NV0002603	NEWMONT GOLD NORTH AREA LEACH	300	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0000908	NEWMONT MIDAS MINE	200	GROUNDWATER	2	WELL(S)		
DOUGLAS	NON-TRANSIENT NON-COMMUNITY	NV0000977	NORTH COUNTY WATER SYSTEM	200	GROUNDWATER	2	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000870	NORTH VALLEY BUS FACILITY	60	GROUNDWATER	1	WELL(S)		
HUMBOLDT	NON-TRANSIENT NON-COMMUNITY	NV0002513	NORTH VALMY POWER PLANT	120	GROUNDWATER	2	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0002152	NYE COUNTY COMPLEX	100	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0003036	PAHRUMP SENIOR CENTER INC	70	GROUNDWATER	1	WELL(S)		
HUMBOLDT	NON-TRANSIENT NON-COMMUNITY	NV0002186	PARADISE VALLEY ELEMENTARY	45	GROUNDWATER	1	WELL(S)		
LANDER	NON-TRANSIENT NON-COMMUNITY	NV0000902	PHOENIX MINE POTABLE WATER SYSTEM	400	GROUNDWATER	1	WELL(S)		
HUMBOLDT	NON-TRANSIENT NON-COMMUNITY	NV0002528	PLACER TURQUOISE RIDGE INC	250	GROUNDWATER	1	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000750	PLEASANT VALLEY SCHOOL	300	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0003013	QUEENSTAKE JERRITT CANYON MINE	125	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0000313	QUEENSTAKE SSX MINE	125	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0001042	RIVERSIDE RESORT	3,000	GROUNDWATER	3	WELL(S)		
WHITE PINE	NON-TRANSIENT NON-COMMUNITY	NV0000855	ROBINSON NEVADA MINING COMPANY	450	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0003070	RUBY VALLEY LDS CHAPEL	40	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0002084	RUBY VALLEY SCHOOL	30	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0002566	SAGE SCHOOLS	2,200	GROUNDWATER	2	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0004001	SANDY VALLEY ELEMENTARY SCHOOL	230	GROUNDWATER	1	WELL(S)		
MINERAL	NON-TRANSIENT NON-COMMUNITY	NV0000897	SCHURZ ELEMENTARY SCHOOL	320	GROUNDWATER	1	WELL(S)		
LYON	NON-TRANSIENT NON-COMMUNITY	NV0002595	SILVER SPRINGS CONSERVATION CAMP NDOP	144	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0000342	SILVERHAWK POWER PLANT	25	GROUNDWATER	1	WELL(S)		
LYON	NON-TRANSIENT NON-COMMUNITY	NV0002189	SMITH VALLEY SCHOOLS	500	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0002535	SMOKY VALLEY MINE	660	GROUNDWATER	3	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0000289	SOUTHERN NEVADA WATER SYSTEM	200	SURFACE WATER	2	INTAKE(S)		
CARSON CITY	NON-TRANSIENT NON-COMMUNITY	NV0004084	STEWART COMPLEX	300	GROUNDWATER	1	WELL(S)		
STOREY	NON-TRANSIENT NON-COMMUNITY	NV0000913	TAHOE RENO INDUSTRIAL CENTER	900	GROUNDWATER	3	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0000834	TERRIBLES RANCH CASINO AND RV PARK	25	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0000804	TOLICHA PEAK ELECTRONIC COMBAT RANGE	80	GROUNDWATER	1	WELL(S)		
EUREKA	NON-TRANSIENT NON-COMMUNITY	NV0000404	TONKIN SPRINGS LABOR CAMP	40	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0000823	TONOPAH CONSERVATION CAMP NDOP	150	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0005002	TONOPAH ELECTRONIC COMBAT RANGE O AND M	127	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0005001	TONOPAH TEST RANGE AREA 10	130	GROUNDWATER	3	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0004068	TONOPAH TEST RANGE MANCAMP	30	GROUNDWATER	2	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0003014	TONOPAH TEST RANGE SITE 6	150	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
STOREY	NON-TRANSIENT NON-COMMUNITY	NV0002596	TRACY POWER STATION	87	GROUNDWATER	2	WELL(S)		
PERSHING	NON-TRANSIENT NON-COMMUNITY	NV0002159	TRAVEL CENTERS OF AMERICA NO 181	1,001	GROUNDWATER	1	WELL(S)		
CLARK	NON-TRANSIENT NON-COMMUNITY	NV0001059	TROPICANA HOTEL	5,950	GROUNDWATER	2	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000978	TRUCKEE CANYON WATER SYSTEM	25	GROUNDWATER	1	WELL(S)		
EUREKA	NON-TRANSIENT NON-COMMUNITY	NV0000403	TS POWER PLANT	750	GROUNDWATER	1	WELL(S)		
HUMBOLDT	NON-TRANSIENT NON-COMMUNITY	NV0005070	TWIN CREEKS	600	GROUNDWATER	1	WELL(S)		
HUMBOLDT	NON-TRANSIENT NON-COMMUNITY	NV0002098	US FOODS	70	GROUNDWATER	1	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0005061	VERDI BUSINESS PARK WATER CO OP	100	GROUNDWATER	1	WELL(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0000773	VERDI MUTUAL WATER COMPANY	300	GROUNDWATER	1	SPRING(S)		
WASHOE	NON-TRANSIENT NON-COMMUNITY	NV0003000	VERDI SCHOOL	250	GROUNDWATER	1	WELL(S)		
ELKO	NON-TRANSIENT NON-COMMUNITY	NV0005005	WELLS HONOR CAMP NDOP	150	GROUNDWATER	1	WELL(S)		
DOUGLAS	NON-TRANSIENT NON-COMMUNITY	NV0000816	WILLIAMS RIDGE TECH PARK	60	GROUNDWATER	1	WELL(S)		
NYE	NON-TRANSIENT NON-COMMUNITY	NV0000867	YUCCA MOUNTAIN SITE	125	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
DOUGLAS	NON-TRANSIENT NON-COMMUNITY	NV0002059	ZEPHYR COVE LODGE AND RESORT	500	GROUNDWATER	3	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000735	4TH STREET BISTRO	30	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000702	ACE APARTMENTS	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000703	AIR BASE INN	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000866	AIR SAILING INC GLIDERPORT	25	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
NYE	TRANSIENT NON-COMMUNITY	NV0000828	AMARGOSA PARK	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002141	AMARGOSA VALLEY RESORT INC	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000811	AMARGOSA VALLEY VFW POST 6826	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002088	ANGEL CREEK CAMPGROUND USFS	75	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0003037	ANGEL LAKE CAMPGROUND USFS	100	GROUNDWATER	1	SPRING(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0003010	BAILEYS HOT SPRINGS	25	GROUNDWATER	1	SPRING(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0003052	BAKER CREEK CAMPGROUND NPS	45	GROUNDWATER	1	SPRING(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000720	BAR M BAR	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0005038	BEATTY RV PARK	25	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0002120	BEAVER DAM STATE PARK	48	GROUNDWATER	1	SPRING(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000339	BELLES TEA COTTAGE	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002151	BERLIN ICTHYOSAUR STATE PARK	67	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000736	BIGLIERI WATER SYSTEM	50	GROUNDWATER	2	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000381	BLACK ROCK STATION	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000323	BLUE DIAMOND SALOON	100	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000955	BLUE DIAMOND TRAVEL CENTER	25	GROUNDWATER	1	WELL(S)		
LANDER	TRANSIENT NON-COMMUNITY	NV0003066	BOB SCOTT CAMPGROUND USFS	25	GROUNDWATER	1	WELL(S)		
ESMERALDA	TRANSIENT NON-COMMUNITY	NV0002090	BOONIES	50	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0005059	BORDER INN	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000710	BOWERS MANSION	100	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000321	BRANDOS SPORTS BAR	100	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0004071	BSA CAMP MT POTOSI	300	GROUNDWATER	2	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0000389	BYBEE 4H MAINTENANCE	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000346	CABO CANTINA AND GRILL	25	GROUNDWATER	1	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0004033	CAMP GALILEE	30	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0002509	CAMP LADY OF THE SNOWS	60	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0004050	CAMP LAMOILLE LIONS CLUB	50	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0005009	CAMP LEE CANYON	150	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
CLARK	TRANSIENT NON-COMMUNITY	NV0002502	CAMP POTOSI CLARK CO	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000405	CARBERRY SQUARE	25	GROUNDWATER	1	WELL(S)		
CARSON CITY	TRANSIENT NON-COMMUNITY	NV0002000	CARSON CITY HOT SPRINGS	75	GROUNDWATER	1	SPRING(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0000952	CARSON PLAINS CASINO	1,001	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002140	CARVERS CAFE	50	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0004035	CAVE LAKE STATE PARK	400	GROUNDWATER	1	SPRING(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0000301	CAVE SPRINGS WATER SYSTEM	25	GROUNDWATER	1	SPRING(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0002128	CG BAR	25	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
NYE	TRANSIENT NON-COMMUNITY	NV0002555	CHAMPIONS	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0005035	CHARLESTON PIZZA FACTORY	25	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0002165	CHERRY CREEK WATER DISTRICT	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0004085	CHICKEN RANCH	25	GROUNDWATER	2	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002554	CHIPMUNK RETREAT	60	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0004079	CHUCKS CIRCLE C MARKET	25	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0005020	CHURCHILL BUTTE COMPLEX	25	GROUNDWATER	1	WELL(S)		
MINERAL	TRANSIENT NON-COMMUNITY	NV0002206	CLIFF HOUSE LAKESIDE RESORT	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000336	CLUB HOUSE TAVERN	50	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002017	COLD SPRINGS STATION	25	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0002113	COMMUNITY HALL PARADISE VALLEY	72	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002565	COYOTE CORNER MARKET	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000717	CROSBYS LODGE	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002588	CRYSTAL PARK NYE COUNTY PARK	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000718	CRYSTAL PEAK PARK	30	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0003060	CRYSTAL SPRINGS BAR RESTAURANT	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002068	CURRIE STORE	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000719	DAVIS CREEK PARK	100	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
CLARK	TRANSIENT NON-COMMUNITY	NV0001078	DEER CREEK SPRING USFS	150	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0000001	DENIO JUNCTION	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001008	DESERT SOUTHWEST CONFERENCE	30	GROUNDWATER	1	WELL(S)		
EUREKA	TRANSIENT NON-COMMUNITY	NV0004044	DIAMOND COUNTRY ROADS	25	GROUNDWATER	1	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0002540	DOUGLAS COUNTY FAIRGROUNDS	725	GROUNDWATER	1	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0002043	DOUGLAS COUNTY LAMPE PARK	200	GROUNDWATER	1	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0002044	DOUGLAS COUNTY TOPAZ PARK	100	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0002593	DRESSLER PARK	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002080	DUNNS WILDHORSE RESORT	50	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000380	DUST DEVIL PIZZA	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000721	DUTCH WIFE MOTEL	50	GROUNDWATER	1	WELL(S)		
ESMERALDA	TRANSIENT NON-COMMUNITY	NV0000916	DYER BAR AND CAFE	25	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0000188	EAGLE VALLEY RESORT PAT AND JOHNS	25	GROUNDWATER	2	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0003098	EAST 50 BAR	25	GROUNDWATER	1	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0002218	EAST PEAK LODGE	2,000	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0002123	ECHO CANYON STATE PARK	196	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000923	ELKS LODGE PAHRUMP	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0002507	ERNIE DS BAR	35	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
ESMERALDA	TRANSIENT NON-COMMUNITY	NV0000890	ESMERALDA MARKET	25	GROUNDWATER	2	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002016	FALLON GOLF COURSE	25	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002594	FALLON LIVESTOCK EXCHANGE	25	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002534	FALLON RV PARK	25	GROUNDWATER	2	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0005019	FAR EAST BAR	25	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0002170	FIRESIDE INN	50	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001053	FLOYD LAMB STATE PARK	100	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000385	FLYING EAGLE 2 STORE	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000155	FORT AMARGOSA RV PARK	25	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0002132	FORT CHURCHILL HISTORIC STATE PARK	207	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000893	FRANKTOWN MEADOWS	25	GROUNDWATER	2	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000386	FREDDYS	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0003029	FRONTIER GIRL SCOUT CAMP	200	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002587	GAS STORE WEST	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0004064	GOLDEN VALLEY PARK	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0003091	HAWKS NEST BAR	25	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0004037	HEYDAY INN	25	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0000961	HIDDEN CANYON RANCH	30	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
NYE	TRANSIENT NON-COMMUNITY	NV0000833	HORIZON MARKET I	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000918	HORIZON MARKET III	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000391	HUNGRY JOSES RESTAURANT	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0004073	IDLE SPURS LOUNGE AND RESTAURANT	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000378	INDIAN SPRINGS AFB SILVER FLAG ALPHA	35	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002143	IONE WATER SYSTEM	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000789	J AND K HOFFMAN	50	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002069	JACK CREEK LODGE	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0002599	JACKSON FOOD STORE 23	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002071	JIGGS BAR	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000731	JOHNNYS LITTLE ITALY RESTAURANT	150	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000886	JUST COUNTRY BAR	25	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0002121	KERSHAW RYAN STATE PARK	25	GROUNDWATER	1	SPRING(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0002174	KOA OF ELY CAMPGROUND	50	GROUNDWATER	2	WELL(S)		
LANDER	TRANSIENT NON-COMMUNITY	NV0000345	L AND N CUSTOM MEAT CUTTING	25	GROUNDWATER	1	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0002053	LA FERME RESTAURANT	25	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002028	LAHONTAN DAM STATE PARK	26	GROUNDWATER UNDER INFLUENCE OF SURFACE WATER	2	SPRING(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
LYON	TRANSIENT NON-COMMUNITY	NV0002133	LAHONTAN DAM STATE PARK BEACH 3	681	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0005021	LAHONTAN DAM STATE PARK BEACH 7	305	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000942	LAKER PLAZA INC	25	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0004055	LANES TRAVEL CENTER	50	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000374	LAS VEGAS MOTOR SPEEDWAY	400	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
CLARK	TRANSIENT NON-COMMUNITY	NV0000307	LAS VEGAS SKI AND SNOWBOARD RESORT	500	GROUNDWATER	2	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0000341	LAST RESORT RESTAURANT	25	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0000938	LATTIN FARMS	25	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0003051	LEHMAN CREEK CAMPGROUND NPS	60	GROUNDWATER	1	SPRING(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0004077	LEMMON VALLEY HORSEMANS PARK	100	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0000857	LINDAS WABUSKA BAR	25	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0002192	LITTLE A LE INN	60	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0004096	LONE MOUNTAIN STATION	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000392	LOVELL CANYON RESIDENTIAL LLC	35	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000917	LOW LOW LIQUOR CIGARETTES AND GOODIES	25	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0002220	LYE CREEK CAMPGROUND USFS	25	GROUNDWATER	1	SPRING(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000738	MAGIC CARPET GOLF	25	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0002175	MAJORS STATION	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0002508	MCWILLIAMS WATER SYSTEM USFS	2,500	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000757	MELS DINER	1,000	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000950	MEMORIAL POINT STATE PARK	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000742	MERRY WINK MOTEL	30	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0003071	MIDAS WATER COOPERATIVE	25	GROUNDWATER	2	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002027	MIDDLEGATE STATION	25	GROUNDWATER	1	WELL(S)		
CARSON CITY	TRANSIENT NON-COMMUNITY	NV0002006	MILLHOUSE INN MOTEL	50	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002142	MOOSE LODGE 808	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001082	MOUNTAIN SPRINGS BAR INC	75	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001010	MT CHARLESTON RESTAURANT AND LODGE	450	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000743	MT ROSE CAMPGROUND USFS	25	GROUNDWATER	1	SPRING(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000744	MT ROSE SKI AREA SKI RENO	800	GROUNDWATER	1	SPRING(S)		
EUREKA	TRANSIENT NON-COMMUNITY	NV0002214	NDOT BEOWAWE ROADSIDE PARK RP802 EU	200	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002147	NDOT BIG SMOKEY ROADSIDE PARK RP807NY	25	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0001054	NDOT BUTTON POINT ROADSIDE PARK RP808HU	200	GROUNDWATER	1	WELL(S)		
PERSHING	TRANSIENT NON-COMMUNITY	NV0002160	NDOT COSGRAVE ROADSIDE PARK RP804PE	80	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002146	NDOT LATHROP WELLS ROADSIDE PARK RP801NY	50	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0002179	NDOT MCGILL HWY ROADSIDE PARK RP809WP	25	GROUNDWATER	1	WELL(S)		
ESMERALDA	TRANSIENT NON-COMMUNITY	NV0002089	NDOT MILLERS NV ROADSIDE PARK RP801ES	100	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000943	NDOT SUNNYSIDE ROADSIDE PARK RP810NY	25	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002034	NDOT TRINITY ROADSIDE PARK RP806CH	100	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0002102	NDOT VALMY ROADSIDE PARK RP809HU	200	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0004022	NDOT WADSWORTH REST STOP	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0004099	NEVADA TEST SITE AREA 12	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0004078	NEW WASHOE CITY PARK	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0003004	NPS LAS VEGAS BAY	25	PURCHASED SURFACE WATER	1	CONSECUTIVE CONNECTION		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0000921	OASIS SPRINGS	25	GROUNDWATER	1	WELL(S)		
STOREY	TRANSIENT NON-COMMUNITY	NV0004046	OLD BRIDGE RANCH	30	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000797	OLD FORTY WEST MOTEL	48	GROUNDWATER	2	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000705	OLD WASHOE STATION	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0003035	OUR BAR	25	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0002106	PARADISE VALLEY PARK	40	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002064	PETES BAR 7 CLUB	26	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001012	PIONEER SALOON	25	GROUNDWATER	1	WELL(S)		
MINERAL	TRANSIENT NON-COMMUNITY	NV0000388	PLAYMATE RANCH	25	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
NYE	TRANSIENT NON-COMMUNITY	NV0000853	QUICK SAVE MARKET	25	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0002119	R PLACE LITTLE ASH SPRINGS	25	GROUNDWATER	1	SPRING(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0000876	RAINBOW CANYON NARCONON	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001069	RANCH HOUSE	25	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0000898	RAPPORT EXECUTIVE RETREAT	25	GROUNDWATER	2	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0005011	RED ROCK CANYON VISITOR CENTER	300	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0003001	RIVERBELLE PROPERTIES LLC CEDARS	25	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0000951	ROSIES PLACE	25	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0002542	ROYAL PEACOCK RV PARK	50	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0000904	RUBY LAKE RESORT	25	GROUNDWATER	1	WELL(S)		
PERSHING	TRANSIENT NON-COMMUNITY	NV0002223	RYE PATCH STATE PARK	199	GROUNDWATER	1	WELL(S)		
PERSHING	TRANSIENT NON-COMMUNITY	NV0005023	RYE PATCH STATE PARK PICNIC AREA	60	GROUNDWATER	1	WELL(S)		
PERSHING	TRANSIENT NON-COMMUNITY	NV0002222	RYE PATCH TRAVEL CENTER INC	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002075	RYNDON CAMPGROUND WATER SYSTEM	248	GROUNDWATER	1	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0002047	S AND J VENTURES DBA JUNCTION BAR	35	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0000872	SAGE VALLEY RV PARK	25	GROUNDWATER	2	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000746	SAND HARBOR STATE PARK	1,000	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0000306	SANDWINDS RESTAURANT SPORTS BAR	25	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
CLARK	TRANSIENT NON-COMMUNITY	NV0000317	SANDY VALLEY LIBRARY COMM CTR	50	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0000915	SANTA ROSA STATION NFC	25	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0000358	SCHELLBOURNE STATION	25	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0000352	SCOTT SHADY COURT	90	GROUNDWATER	3	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0000844	SEVEN ELEVEN NO 23074	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0005034	SEVEN PALMS RV PARK	120	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000820	SHADY LADY RANCH	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002557	SHARONS	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0005036	SHERIS RANCH	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0003074	SHORT BRANCH	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000375	SHORT LINE EXPRESS MARKET	100	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000798	SILVER SPUR MOTEL	30	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002581	SKIPS MINI MARKET	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000760	SKY TAVERN	50	GROUNDWATER	1	SPRING(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000761	SLIDE MOUNTAIN SKI AREA	200	GROUNDWATER	3	SPRING(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0002569	SMITH VALLEY WATER SYSTEM	25	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0000929	SONIC BURGER	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002209	SOUTH RUBY CAMPGROUND USFS	30	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
ELKO	TRANSIENT NON-COMMUNITY	NV0000873	SOUTHFORK STATE PARK AND RECREATION AREA	25	GROUNDWATER	1	WELL(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0004041	SPOONER LAKE STATE PARK	207	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001071	SPRING MOUNTAIN RANCH STATE PARK	225	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0002124	SPRING VALLEY STATE PARK	386	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0002178	STAGE STOP CAFE	50	GROUNDWATER	1	SPRING(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0004040	STAGECOACH MARKET	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002598	STAGESTOP RESTAURANT	25	GROUNDWATER	1	WELL(S)		
PERSHING	TRANSIENT NON-COMMUNITY	NV0002517	STAR POINT MHP RV PARK	25	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0000808	STONE HOUSE COUNTRY INN	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000329	T AND J INVESTMENTS DBA THE GROVE	50	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002076	TAYLOR CANYON CLUB	70	GROUNDWATER	2	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0003044	TERRACES PICNIC GROUNDS USFS	25	GROUNDWATER	1	SPRING(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0004076	THE LODGE AT GALENA	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000914	THE PATIO CAFE	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0003043	THOMAS CANYON CAMPGROUND USFS	25	GROUNDWATER	1	SPRING(S)		
DOUGLAS	TRANSIENT NON-COMMUNITY	NV0002518	TOPAZ LIQUOR MART	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000829	TOWN HALL BAR	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0000331	TRAILS END GENERAL STORE	225	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
CLARK	TRANSIENT NON-COMMUNITY	NV0000373	TROUT CANYON WATER COMPANY	60	GROUNDWATER	1	SPRING(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000827	TUMBLEWEED TAVERN	25	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002586	UNCLE BRUCES SKATING RINK	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0000910	UNR FIRE SCIENCE ACADEMY IN CARLIN	30	PURCHASED GROUNDWATER	1	CONSECUTIVE CONNECTION		
NYE	TRANSIENT NON-COMMUNITY	NV0002575	VALLEY BAR	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001075	VALLEY OF FIRE STATE PARK	1,000	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0002112	VALMY STATION	25	GROUNDWATER	1	WELL(S)		
CLARK	TRANSIENT NON-COMMUNITY	NV0001087	VEGAS VALLEY TRAVEL CENTER	25	GROUNDWATER	1	WELL(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0002556	VFW PAHRUMP POST 10054	25	GROUNDWATER	1	WELL(S)		
PERSHING	TRANSIENT NON-COMMUNITY	NV0003072	VILLAGE STORE	25	GROUNDWATER	1	WELL(S)		
HUMBOLDT	TRANSIENT NON-COMMUNITY	NV0002543	VIRGIN VALLEY CAMPGROUND	25	GROUNDWATER	1	WELL(S)		
CHURCHILL	TRANSIENT NON-COMMUNITY	NV0002037	WAGON WHEEL BAR	25	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0004048	WALKER RIVER RESORT	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000727	WASHOE GRILL	125	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000793	WASHOE LAKE STATE PARK	467	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000318	WASHOE LAKE STATE PARK NORTH BOAT RAMP	25	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000778	WASHOE MOTEL	32	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0003094	WASHOE REGIONAL SHOOTING RANGE	25	GROUNDWATER	1	WELL(S)		

COUNTY	WATER SYSTEM TYPE	ID NUMBER	PUBLIC WATER SYSTEM NAME	POPULATION SERVED	PRIMARY WATER SOURCE	NUMBER OF SOURCES	SOURCE TYPE	NUMBER OF SOURCES	SOURCE TYPE
ELKO	TRANSIENT NON-COMMUNITY	NV0002078	WELCOME STATION RV PARK LLC	35	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0000376	WELLINGTON DELI AND SWEETWATER COFFEE	25	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0000243	WELLINGTON STATION RESORT	64	GROUNDWATER	1	WELL(S)		
WASHOE	TRANSIENT NON-COMMUNITY	NV0000781	WESTERNER MOTEL	25	GROUNDWATER	1	WELL(S)		
WHITE PINE	TRANSIENT NON-COMMUNITY	NV0003054	WHEELER PEAK CAMPGROUND NPS	60	GROUNDWATER	1	SPRING(S)		
NYE	TRANSIENT NON-COMMUNITY	NV0000946	WHOS DUNES	25	GROUNDWATER	1	WELL(S)		
LYON	TRANSIENT NON-COMMUNITY	NV0000881	WILDHORSE BAR AND GRILL	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0003059	WILDHORSE STATE PARK AND RECREATION AREA	25	GROUNDWATER	1	WELL(S)		
ELKO	TRANSIENT NON-COMMUNITY	NV0002211	WILSON RESERVOIR BLM CAMPGROUND	30	GROUNDWATER	1	WELL(S)		
LINCOLN	TRANSIENT NON-COMMUNITY	NV0000399	WINDMILL RIDGE RESTAURANT AND LODGE	25	GROUNDWATER	1	WELL(S)		

# Annual Compliance Detail Report

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000703	AIR BASE INN	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WASHOE
Total Number of Violations for This Water System: 1							
NV0000866	AIR SAILING INC GLIDERPORT	3100	COLIFORM, TOTAL (TCR)	22	04/01/2006 06/30/2006	7/19/2006	WASHOE
Total Number of Violations for This Water System: 1							
NV0000005	ALAMO SEWER AND WATER GID	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		LINCOLN
Total Number of Violations for This Water System: 1							
NV0000879	ALCOA MICROMILL	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		STOREY
Total Number of Violations for This Water System: 1							
NV0000077	ALIEN COWPOKE	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 12/31/2006	6/27/2007	LINCOLN
Total Number of Violations for This Water System: 1							
NV0002141	AMARGOSA VALLEY RESORT INC	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		NYE
Total Number of Violations for This Water System: 1							
NV0002558	AMARGOSA VALLEY WATER ASSOCIATION	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 04/30/2006		NYE
NV0002558	AMARGOSA VALLEY WATER ASSOCIATION	3100	COLIFORM, TOTAL (TCR)	25	03/31/2006 04/29/2006		NYE
NV0002558	AMARGOSA VALLEY WATER ASSOCIATION	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002558	AMARGOSA VALLEY WATER ASSOCIATION	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		NYE
Total Number of Violations for This Water System: 4							
NV0002088	ANGEL CREEK CAMPGROUND USFS	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 09/30/2006		ELKO
Total Number of Violations for This Water System: 1							
NV0000863	BAKER WATER AND SEWER GID	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 07/31/2006		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0002120	BEAVER DAM STATE PARK	3100	COLIFORM, TOTAL (TCR)	22	08/01/2006 08/31/2006		LINCOLN
NV0002120	BEAVER DAM STATE PARK	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		LINCOLN
Total Number of Violations for This Water System: 2							
NV0000362	BIG FIVE PARK	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 04/30/2006		NYE
NV0000362	BIG FIVE PARK	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 07/31/2006		NYE
Total Number of Violations for This Water System: 2							
NV0000369	BIG VALLEY MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		NYE
Total Number of Violations for This Water System: 1							
NV0000736	BIGLIERI WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006	7/19/2006	WASHOE
NV0000736	BIGLIERI WATER SYSTEM	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WASHOE
NV0000736	BIGLIERI WATER SYSTEM	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
<b>Total Number of Violations for This Water System: 3</b>							
NV0000381	BLACK ROCK STATION	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		WASHOE
<b>Total Number of Violations for This Water System: 1</b>							
NV0000955	BLUE DIAMOND TRAVEL CENTER	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		CLARK
<b>Total Number of Violations for This Water System: 1</b>							
NV0001001	BONNIE SPRINGS OLD NEVADA	3100	COLIFORM, TOTAL (TCR)	23	09/01/2006 09/30/2006		CLARK
<b>Total Number of Violations for This Water System: 1</b>							
NV0005059	BORDER INN	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		WHITE PINE
<b>Total Number of Violations for This Water System: 1</b>							
NV0000364	BPB GYPSUM INC	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		CLARK
NV0000364	BPB GYPSUM INC	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CLARK
NV0000364	BPB GYPSUM INC	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		CLARK
<b>Total Number of Violations for This Water System: 3</b>							
NV0000896	BRISTLECONE FAMILY RESOURCES	5000	LEAD & COPPER RULE	52	01/01/2006 12/31/2006		WASHOE
<b>Total Number of Violations for This Water System: 1</b>							
NV0000389	BYBEE 4H MAINTENANCE	3100	COLIFORM, TOTAL (TCR)	22	04/01/2006 06/30/2006		LYON
<b>Total Number of Violations for This Water System: 1</b>							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002538	C VALLEY MHP	0999	CHLORINE	27	04/01/2006 04/30/2006		NYE
NV0002538	C VALLEY MHP	0999	CHLORINE	27	07/01/2006 07/31/2006		NYE
NV0002538	C VALLEY MHP	0999	CHLORINE	27	10/01/2006 10/31/2006		NYE
NV0002538	C VALLEY MHP	0999	CHLORINE	27	09/01/2006 09/30/2006		NYE
NV0002538	C VALLEY MHP	0999	CHLORINE	27	11/01/2006 11/30/2006		NYE
NV0002538	C VALLEY MHP	0999	CHLORINE	27	06/01/2006 06/30/2006		NYE
NV0002538	C VALLEY MHP	0999	CHLORINE	27	12/01/2006 12/31/2006		NYE
NV0002538	C VALLEY MHP	0999	CHLORINE	27	05/01/2006 05/31/2006		NYE
NV0002538	C VALLEY MHP	0999	CHLORINE	27	08/01/2006 08/31/2006		NYE
NV0002538	C VALLEY MHP	3100	COLIFORM, TOTAL (TCR)	22	09/01/2006 09/30/2006		NYE
NV0002538	C VALLEY MHP	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 07/31/2006		NYE
NV0002538	C VALLEY MHP	3100	COLIFORM, TOTAL (TCR)	23	08/01/2006 08/31/2006		NYE
NV0002538	C VALLEY MHP	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 04/30/2006		NYE
NV0002538	C VALLEY MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		NYE
NV0002538	C VALLEY MHP	2456	TOTAL HALOACETIC ACIDS (HAA5)	27	01/01/2006 12/31/2006		NYE
NV0002538	C VALLEY MHP	2950	TOTAL TRIHALOMETHANES (TTHM)	27	01/01/2006 12/31/2006		NYE
<b>Total Number of Violations for This Water System: 16</b>							
NV0000346	CABO CANTINA AND GRILL	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000346	CABO CANTINA AND GRILL	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CLARK
Total Number of Violations for This Water System: 2							
NV0000013	CALIENTE PUBLIC UTILITIES	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		LINCOLN
NV0000013	CALIENTE PUBLIC UTILITIES	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		LINCOLN
NV0000013	CALIENTE PUBLIC UTILITIES	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		LINCOLN
NV0000013	CALIENTE PUBLIC UTILITIES	4020	RADIUM-226	03	10/01/2006 12/31/2006		LINCOLN
NV0000013	CALIENTE PUBLIC UTILITIES	4030	RADIUM-228	03	10/01/2006 12/31/2006		LINCOLN
NV0000013	CALIENTE PUBLIC UTILITIES	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		LINCOLN
Total Number of Violations for This Water System: 6							
NV0002509	CAMP LADY OF THE SNOWS	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 04/30/2006		CLARK
Total Number of Violations for This Water System: 1							
NV0002502	CAMP POTOSI CLARK CO	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		CLARK
NV0002502	CAMP POTOSI CLARK CO	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CLARK
Total Number of Violations for This Water System: 2							
NV0003068	CARSON RIVER ESTATES	0999	CHLORINE	27	09/01/2006 09/30/2006		CHURCHILL
NV0003068	CARSON RIVER ESTATES	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 07/31/2006		CHURCHILL
NV0003068	CARSON RIVER ESTATES	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0003068	CARSON RIVER ESTATES	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		CHURCHILL
NV0003068	CARSON RIVER ESTATES	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		CHURCHILL
NV0003068	CARSON RIVER ESTATES	4020	RADIUM-226	03	10/01/2006 12/31/2006		CHURCHILL
NV0003068	CARSON RIVER ESTATES	4030	RADIUM-228	03	10/01/2006 12/31/2006		CHURCHILL
NV0003068	CARSON RIVER ESTATES	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		CHURCHILL
<b>Total Number of Violations for This Water System: 8</b>							
NV0002140	CARVERS CAFE	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		NYE
NV0002140	CARVERS CAFE	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		NYE
NV0002140	CARVERS CAFE	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006	11/8/2006	NYE
<b>Total Number of Violations for This Water System: 3</b>							
NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		NYE
<b>Total Number of Violations for This Water System: 1</b>							
NV0000390	CENTRAL JUNCTION BAR AND CAFE	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		LYON
NV0000390	CENTRAL JUNCTION BAR AND CAFE	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		LYON
<b>Total Number of Violations for This Water System: 2</b>							
NV0002555	CHAMPIONS	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		NYE
NV0002555	CHAMPIONS	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002555	CHAMPIONS	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		NYE
NV0002555	CHAMPIONS	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		NYE
NV0002555	CHAMPIONS	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		NYE
<b>Total Number of Violations for This Water System: 5</b>							
NV0005035	CHARLESTON PIZZA FACTORY	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		NYE
NV0005035	CHARLESTON PIZZA FACTORY	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		NYE
<b>Total Number of Violations for This Water System: 2</b>							
NV0002554	CHIPMUNK RETREAT	3100	COLIFORM, TOTAL (TCR)	22	01/01/2006 03/31/2006	5/17/2006	NYE
NV0002554	CHIPMUNK RETREAT	3100	COLIFORM, TOTAL (TCR)	23	02/01/2006 02/28/2006	5/17/2006	NYE
<b>Total Number of Violations for This Water System: 2</b>							
NV0005020	CHURCHILL BUTTE COMPLEX	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		LYON
NV0005020	CHURCHILL BUTTE COMPLEX	1040	NITRATE (AS N)	03	04/01/2006 06/30/2006		LYON
NV0005020	CHURCHILL BUTTE COMPLEX	1040	NITRATE (AS N)	03	07/01/2006 09/30/2006		LYON
<b>Total Number of Violations for This Water System: 3</b>							
NV0000813	CHURCHILL RANCHOS ESTATES	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		LYON
NV0000813	CHURCHILL RANCHOS ESTATES	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		LYON
NV0000813	CHURCHILL RANCHOS ESTATES	4020	RADIUM-226	03	07/01/2006 09/30/2006		LYON
NV0000813	CHURCHILL RANCHOS ESTATES	4020	RADIUM-226	03	07/01/2006 09/30/2006		LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000813	CHURCHILL RANCHOS ESTATES	4030	RADIUM-228	03	07/01/2006 09/30/2006		LYON
NV0000813	CHURCHILL RANCHOS ESTATES	4030	RADIUM-228	03	07/01/2006 09/30/2006		LYON
Total Number of Violations for This Water System: 6							
NV0000102	CITY VUE MHP	3100	COLIFORM, TOTAL (TCR)	23	09/01/2006 09/30/2006		CLARK
Total Number of Violations for This Water System: 1							
NV0002206	CLIFF HOUSE LAKESIDE RESORT	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		MINERAL
Total Number of Violations for This Water System: 1							
NV0005057	COLD CREEK MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0000892	CORTEZ GOLD MINES PIPELINE	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		LANDER
Total Number of Violations for This Water System: 1							
NV0002144	COTTON PICKIN CASINO	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006	2/2/2007	NYE
Total Number of Violations for This Water System: 1							
NV0000017	COTTONWOOD MHP	3100	COLIFORM, TOTAL (TCR)	23	12/01/2006 12/31/2006	3/1/2007	CARSON CITY
NV0000017	COTTONWOOD MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CARSON CITY
Total Number of Violations for This Water System: 2							
NV0000046	COUNTRY CLUB ESTATES	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
<b>Total Number of Violations for This Water System: 1</b>							
NV0002565	COYOTE CORNER MARKET	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		NYE
<b>Total Number of Violations for This Water System: 1</b>							
NV0000043	CRESCENT VALLEY WATER SYSTEM	0999	CHLORINE	27	01/01/2006 01/31/2006		EUREKA
NV0000043	CRESCENT VALLEY WATER SYSTEM	0999	CHLORINE	27	04/01/2006 04/30/2006		EUREKA
NV0000043	CRESCENT VALLEY WATER SYSTEM	0999	CHLORINE	27	06/01/2006 06/30/2006		EUREKA
NV0000043	CRESCENT VALLEY WATER SYSTEM	0999	CHLORINE	27	05/01/2006 05/31/2006		EUREKA
NV0000043	CRESCENT VALLEY WATER SYSTEM	0999	CHLORINE	27	02/01/2006 02/28/2006		EUREKA
NV0000043	CRESCENT VALLEY WATER SYSTEM	0999	CHLORINE	27	07/01/2006 07/31/2006		EUREKA
NV0000043	CRESCENT VALLEY WATER SYSTEM	0999	CHLORINE	27	09/01/2006 09/30/2006		EUREKA
NV0000043	CRESCENT VALLEY WATER SYSTEM	0999	CHLORINE	27	03/01/2006 03/31/2006		EUREKA
NV0000043	CRESCENT VALLEY WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 07/31/2006	9/28/2006	EUREKA
<b>Total Number of Violations for This Water System: 9</b>							
NV0000864	CROFOOT MINE HYCROFT RESOURCES	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 09/30/2006		HUMBOLDT
NV0000864	CROFOOT MINE HYCROFT RESOURCES	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		HUMBOLDT
<b>Total Number of Violations for This Water System: 2</b>							
NV0000361	CRYSTAL CLEAR WATER COMPANY	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 04/30/2006	5/23/2006	LYON
NV0000361	CRYSTAL CLEAR WATER COMPANY	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		LYON
<b>Total Number of Violations for This Water System: 2</b>							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0003060	CRYSTAL SPRINGS BAR RESTAURANT	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		NYE
Total Number of Violations for This Water System: 1							
NV0000193	CRYSTAL TP	3100	COLIFORM, TOTAL (TCR)	23	05/01/2006 05/31/2006		WASHOE
NV0000193	CRYSTAL TP	3100	COLIFORM, TOTAL (TCR)	23	06/01/2006 06/30/2006		WASHOE
NV0000193	CRYSTAL TP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		WASHOE
NV0000193	CRYSTAL TP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		WASHOE
NV0000193	CRYSTAL TP	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WASHOE
NV0000193	CRYSTAL TP	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		WASHOE
NV0000193	CRYSTAL TP	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		WASHOE
NV0000193	CRYSTAL TP	4020	RADIUM-226	03	04/01/2006 06/30/2006		WASHOE
NV0000193	CRYSTAL TP	4020	RADIUM-226	03	07/01/2006 09/30/2006		WASHOE
NV0000193	CRYSTAL TP	4030	RADIUM-228	03	07/01/2006 09/30/2006		WASHOE
NV0000193	CRYSTAL TP	4030	RADIUM-228	03	04/01/2006 06/30/2006		WASHOE
NV0000193	CRYSTAL TP	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		WASHOE
NV0000193	CRYSTAL TP	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		WASHOE
Total Number of Violations for This Water System: 13							
NV0000033	DAYTON VALLEY MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000033	DAYTON VALLEY MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4020	RADIUM-226	03	07/01/2006 09/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4020	RADIUM-226	03	07/01/2006 09/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4020	RADIUM-226	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4020	RADIUM-226	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4030	RADIUM-228	03	07/01/2006 09/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4030	RADIUM-228	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4030	RADIUM-228	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4030	RADIUM-228	03	07/01/2006 09/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		LYON
NV0000033	DAYTON VALLEY MHP	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
<b>Total Number of Violations for This Water System: 20</b>							
NV0001078	DEER CREEK SPRING USFS	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CLARK
<b>Total Number of Violations for This Water System: 1</b>							
NV0000047	DELUXE MHP	0999	CHLORINE	27	03/01/2006 03/31/2006		CHURCHILL
NV0000047	DELUXE MHP	3100	COLIFORM, TOTAL (TCR)	22	06/01/2006 06/30/2006		CHURCHILL
NV0000047	DELUXE MHP	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 07/31/2006		CHURCHILL
NV0000047	DELUXE MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL
NV0000047	DELUXE MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4020	RADIUM-226	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4020	RADIUM-226	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4030	RADIUM-228	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4030	RADIUM-228	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		CHURCHILL
NV0000047	DELUXE MHP	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		CHURCHILL
<b>Total Number of Violations for This Water System: 14</b>							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000001	DENIO JUNCTION	3100	COLIFORM, TOTAL (TCR)	22	04/01/2006 06/30/2006		HUMBOLDT
NV0000001	DENIO JUNCTION	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		HUMBOLDT
NV0000001	DENIO JUNCTION	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		HUMBOLDT
Total Number of Violations for This Water System: 3							
NV0000831	DESERT MIRAGE HOMEOWNERS ASSOCIATION	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 04/30/2006		NYE
Total Number of Violations for This Water System: 1							
NV0000149	DESERT PARADISE MHP	3100	COLIFORM, TOTAL (TCR)	23	06/01/2006 06/30/2006		CLARK
NV0000149	DESERT PARADISE MHP	3100	COLIFORM, TOTAL (TCR)	23	09/01/2006 09/30/2006		CLARK
NV0000149	DESERT PARADISE MHP	3100	COLIFORM, TOTAL (TCR)	23	05/01/2006 05/31/2006		CLARK
NV0000149	DESERT PARADISE MHP	5000	LEAD & COPPER RULE	52	01/01/2006 12/31/2006		CLARK
Total Number of Violations for This Water System: 4							
NV0004044	DIAMOND COUNTRY ROADS	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 09/30/2006		EUREKA
NV0004044	DIAMOND COUNTRY ROADS	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 10/31/2006		EUREKA
NV0004044	DIAMOND COUNTRY ROADS	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		EUREKA
NV0004044	DIAMOND COUNTRY ROADS	3100	COLIFORM, TOTAL (TCR)	25	07/01/2006 09/30/2006		EUREKA
NV0004044	DIAMOND COUNTRY ROADS	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		EUREKA
Total Number of Violations for This Water System: 5							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002540	DOUGLAS COUNTY FAIRGROUNDS	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 09/30/2006		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0002593	DRESSLER PARK	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 09/30/2006	10/16/2006	LYON
NV0002593	DRESSLER PARK	3100	COLIFORM, TOTAL (TCR)	22	04/01/2006 06/30/2006	10/16/2006	LYON
Total Number of Violations for This Water System: 2							
NV0000380	DUST DEVIL PIZZA	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CLARK
NV0000380	DUST DEVIL PIZZA	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CLARK
Total Number of Violations for This Water System: 2							
NV0000809	DUTCHMAN ACRES	3100	COLIFORM, TOTAL (TCR)	23	03/01/2006 03/31/2006		PERSHING
NV0000809	DUTCHMAN ACRES	3100	COLIFORM, TOTAL (TCR)	23	08/01/2006 08/31/2006		PERSHING
NV0000809	DUTCHMAN ACRES	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		PERSHING
Total Number of Violations for This Water System: 3							
NV0003075	EAGLE PICHER MINERALS	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		STOREY
NV0003075	EAGLE PICHER MINERALS	1040	NITRATE (AS N)	03	07/01/2006 09/30/2006		STOREY
Total Number of Violations for This Water System: 2							
NV0000188	EAGLE VALLEY RESORT PAT AND JOHNS	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		LINCOLN
Total Number of Violations for This Water System: 1							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0003098	EAST 50 BAR	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006	6/27/2007	LYON
NV0003098	EAST 50 BAR	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006	6/27/2007	LYON
NV0003098	EAST 50 BAR	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006	6/27/2007	LYON
NV0003098	EAST 50 BAR	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		LYON
Total Number of Violations for This Water System: 4							
NV0002216	EAST VALLEY WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	22	01/01/2006 01/31/2006		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0002123	ECHO CANYON STATE PARK	3100	COLIFORM, TOTAL (TCR)	22	08/01/2006 08/31/2006		LINCOLN
NV0002123	ECHO CANYON STATE PARK	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		LINCOLN
Total Number of Violations for This Water System: 2							
NV0000271	ELK POINT COUNTRY CLUB	3100	COLIFORM, TOTAL (TCR)	23	06/01/2006 06/30/2006		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0005071	ELY MAXIMUM SECURITY PRISON NDOP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	3100	COLIFORM, TOTAL (TCR)	22	08/01/2006 08/31/2006		WHITE PINE
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WHITE PINE
Total Number of Violations for This Water System: 2							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002507	ERNIE DS BAR	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 07/31/2006		CLARK
Total Number of Violations for This Water System: 1							
NV0002552	ESCAPEE CO OP OF NEVADA	0999	CHLORINE	27	10/01/2006 10/31/2006		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 01/31/2006		NYE
Total Number of Violations for This Water System: 2							
NV0000249	F AND H TP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		HUMBOLDT
NV0000249	F AND H TP	1040	NITRATE (AS N)	03	07/01/2006 09/30/2006		HUMBOLDT
NV0000249	F AND H TP	1040	NITRATE (AS N)	03	10/01/2006 12/31/2006		HUMBOLDT
Total Number of Violations for This Water System: 3							
NV0000045	FALLON CITY OF	3100	COLIFORM, TOTAL (TCR)	22	12/01/2006 12/31/2006	12/22/2006	CHURCHILL
Total Number of Violations for This Water System: 1							
NV0002016	FALLON GOLF COURSE	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		CHURCHILL
Total Number of Violations for This Water System: 1							
NV0002594	FALLON LIVESTOCK EX CHANGE	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CHURCHILL
NV0002594	FALLON LIVESTOCK EX CHANGE	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		CHURCHILL
Total Number of Violations for This Water System: 2							
NV0002534	FALLON RV PARK	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 09/30/2006		CHURCHILL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 1							
NV0005019	FAR EAST BAR	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		NYE
Total Number of Violations for This Water System: 1							
NV0000062	FERNLEY PUBLIC WORKS	2981	1,1,1- TRICHLOROETHANE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2985	1,1,2- TRICHLOROETHANE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2977	1,1- DICHLOROETHYLENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2378	1,2,4- TRICHLOROBENZENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2980	1,2- DICHLOROETHANE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2983	1,2- DICHLOROPROPANE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2110	2,4,5-TP (SILVEX)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2105	2,4-D	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2051	ALACHLOR (LASSO)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2047	ALDICARB	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2044	ALDICARB SULFONE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2043	ALDICARB SULFOXIDE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2388	AROCLOR 1016 (PCB)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2390	AROCLOR 1221 (PCB)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2392	AROCLOR 1232 (PCB)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2394	AROCLOR 1242 (PCB)	03	07/01/2006 09/30/2006		LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000062	FERNLEY PUBLIC WORKS	2396	AROCLOR 1248 (PCB)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2398	AROCLOR 1254 (PCB)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2400	AROCLOR 1260 (PCB)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2050	ATRAZINE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2990	BENZENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2306	BENZO (A) PYRENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2010	BHC-GAMMA (LINDANE)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2046	CARBOFURAN	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2982	CARBON TETRACHLORIDE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2959	CHLORDANE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2380	CIS-1,2- DICHLOROETHYLENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	3100	COLIFORM, TOTAL (TCR)	22	11/01/2006 11/30/2006	12/15/2006	LYON
NV0000062	FERNLEY PUBLIC WORKS	2031	DALAPON	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2035	DI(2-ETHYLHEXYL) - ADIPATE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2039	DI(2-ETHYLHEXYL) - PHTHALATE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2931	DIBROMOCHLOROPROPANE (DBCP)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2964	DICHLOROMETHANE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2041	DINOSEB	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2032	DIQUAT	03	07/01/2006 09/30/2006		LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000062	FERNLEY PUBLIC WORKS	2033	ENDOTHALL	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2005	ENDRIN	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2992	ETHYLBENZENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2946	ETHYLENE DIBROMIDE (EDB)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2034	GLYPHOSATE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2065	HEPTACHLOR	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2067	HEPTACHLOR EPOXIDE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2274	HEXACHLOROBENZENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2042	HEXACHLOROCYCLOPENTADIE NE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2015	METHOXYCHLOR	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2989	MONOCHLOROBENZENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2968	O- DICHLOROBENZENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2036	OXAMYL (VYDATE)	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2969	P- DICHLOROBENZENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2326	PENTACHLOROPHENOL	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2040	PICLORAM	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2037	SIMAZINE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2996	STYRENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2987	TETRACHLOROETHYLENE	03	07/01/2006 09/30/2006		LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000062	FERNLEY PUBLIC WORKS	2991	TOLUENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2020	TOXAPHENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2979	TRANS-1,2-DICHLOROETHYLENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2984	TRICHLOROETHYLENE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2976	VINYL CHLORIDE	03	07/01/2006 09/30/2006		LYON
NV0000062	FERNLEY PUBLIC WORKS	2955	XYLENES	03	07/01/2006 09/30/2006		LYON
<b>Total Number of Violations for This Water System: 60</b>							
NV0000884	FLORIDA CANYON MINING INC	0999	CHLORINE	27	01/01/2006 03/31/2006		PERSHING
<b>Total Number of Violations for This Water System: 1</b>							
NV0000385	FLYING EAGLE 2 STORE	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		NYE
NV0000385	FLYING EAGLE 2 STORE	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		NYE
NV0000385	FLYING EAGLE 2 STORE	1040	NITRATE (AS N)	01	04/01/2006 06/30/2006	8/1/2006	NYE
<b>Total Number of Violations for This Water System: 3</b>							
NV0005076	FLYING M HUNTING CLUB	1040	NITRATE (AS N)	02	01/01/2006 12/31/2006		LYON
NV0005076	FLYING M HUNTING CLUB	1040	NITRATE (AS N)	02	01/01/2006 12/31/2006		LYON
NV0005076	FLYING M HUNTING CLUB	1040	NITRATE (AS N)	02	01/01/2006 12/31/2006		LYON
<b>Total Number of Violations for This Water System: 3</b>							
NV0000200	FOOTHILL TRAILER PARK	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	01/01/2006 03/31/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000200	FOOTHILL TRAILER PARK	5000	LEAD & COPPER RULE	52	01/01/2006 12/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4010	RADIUM, COMBINED (226, 228)	03	01/01/2006 03/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4020	RADIUM-226	03	10/01/2006 12/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4020	RADIUM-226	03	01/01/2006 03/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4030	RADIUM-228	03	10/01/2006 12/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4030	RADIUM-228	03	01/01/2006 03/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4006	URANIUM, COMBINED	03	01/01/2006 03/31/2006		WASHOE
NV0000200	FOOTHILL TRAILER PARK	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		WASHOE
<b>Total Number of Violations for This Water System: 11</b>							
NV0000959	FOOTHILL WATER SYSTEM	0999	CHLORINE	27	11/01/2006 11/30/2006		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 10/31/2006		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	23	02/01/2006 02/28/2006	3/28/2006	DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 01/31/2006	3/28/2006	DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		DOUGLAS
<b>Total Number of Violations for This Water System: 5</b>							
NV0000155	FORT AMARGOSA RV PARK	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006	6/27/2007	NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000155	FORT AMARGOSA RV PARK	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006	2/26/2007	NYE
Total Number of Violations for This Water System: 2							
NV0002132	FORT CHURCHILL HISTORIC STATE PARK	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 12/31/2006		LYON
Total Number of Violations for This Water System: 1							
NV0000386	FREDDYS	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		NYE
NV0000386	FREDDYS	1040	NITRATE (AS N)	01	01/01/2006 12/31/2006	6/1/2006	NYE
NV0000386	FREDDYS	1040	NITRATE (AS N)	03	11/01/2006 11/30/2006		NYE
Total Number of Violations for This Water System: 3							
NV0003029	FRONTIER GIRL SCOUT CAMP	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006	2/27/2007	CLARK
Total Number of Violations for This Water System: 1							
NV0000063	GABBS WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	23	12/01/2006 12/31/2006		NYE
NV0000063	GABBS WATER SYSTEM	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		NYE
Total Number of Violations for This Water System: 2							
NV0000065	GARDNERVILLE TOWN WATER	3100	COLIFORM, TOTAL (TCR)	22	06/01/2006 06/30/2006		DOUGLAS
NV0000065	GARDNERVILLE TOWN WATER	3100	COLIFORM, TOTAL (TCR)	22	08/01/2006 08/31/2006		DOUGLAS
Total Number of Violations for This Water System: 2							
NV0002587	GAS STORE WEST	3100	COLIFORM, TOTAL (TCR)	25	07/01/2006 09/30/2006		CHURCHILL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
<b>Total Number of Violations for This Water System: 1</b>							
NV0000071	GERLACH GID	2456	TOTAL HALOACETIC ACIDS (HAA5)	27	01/01/2006 12/31/2006		WASHOE
NV0000071	GERLACH GID	2950	TOTAL TRIHALOMETHANES (TTHM)	27	01/01/2006 12/31/2006		WASHOE
<b>Total Number of Violations for This Water System: 2</b>							
NV0000356	GLENBROOK HOMEOWNERS ASSOCIATION	1052	SODIUM	03	01/01/2006 12/31/2006		DOUGLAS
<b>Total Number of Violations for This Water System: 1</b>							
NV0005029	GOLCONDA GID	2981	1,1,1-TRICHLOROETHANE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2985	1,1,2-TRICHLOROETHANE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2977	1,1-DICHLOROETHYLENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2378	1,2,4-TRICHLOROBENZENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2980	1,2-DICHLOROETHANE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2983	1,2-DICHLOROPROPANE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2990	BENZENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2982	CARBON TETRACHLORIDE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	0999	CHLORINE	27	08/01/2006 08/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	0999	CHLORINE	27	12/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	0999	CHLORINE	27	11/01/2006 11/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	0999	CHLORINE	27	09/01/2006 09/30/2006		HUMBOLDT

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0005029	GOLCONDA GID	0999	CHLORINE	27	10/01/2006 10/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	0999	CHLORINE	27	04/01/2006 04/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	0999	CHLORINE	27	06/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	0999	CHLORINE	27	07/01/2006 07/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	0999	CHLORINE	27	05/01/2006 05/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2380	CIS-1,2-DICHLOROETHYLENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2964	DICHLOROMETHANE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2992	ETHYLBENZENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2989	MONOCHLOROBENZENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		HUMBOLDT

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0005029	GOLCONDA GID	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2968	O-DICHLOROBENZENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2969	P-DICHLOROBENZENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4020	RADIUM-226	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4020	RADIUM-226	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4020	RADIUM-226	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4020	RADIUM-226	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4020	RADIUM-226	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4020	RADIUM-226	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4030	RADIUM-228	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4030	RADIUM-228	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4030	RADIUM-228	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4030	RADIUM-228	03	04/01/2006 06/30/2006		HUMBOLDT

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0005029	GOLCONDA GID	4030	RADIUM-228	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4030	RADIUM-228	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2996	STYRENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2987	TETRACHLOROETHYLENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2991	TOLUENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2456	TOTAL HALOACETIC ACIDS (HAA5)	27	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2950	TOTAL TRIHALOMETHANES (TTHM)	27	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2979	TRANS-1,2-DICHLOROETHYLENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2984	TRICHLOROETHYLENE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		HUMBOLDT
NV0005029	GOLCONDA GID	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2976	VINYL CHLORIDE	03	01/01/2006 12/31/2006		HUMBOLDT
NV0005029	GOLCONDA GID	2955	XYLENES	03	01/01/2006 12/31/2006		HUMBOLDT
Total Number of Violations for This Water System: 66							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000751	GOLD RANCH CASINO	0999	CHLORINE	27	12/01/2006 12/31/2006		WASHOE
NV0000751	GOLD RANCH CASINO	0999	CHLORINE	27	10/01/2006 10/31/2006		WASHOE
NV0000751	GOLD RANCH CASINO	0999	CHLORINE	27	11/01/2006 11/30/2006		WASHOE
<b>Total Number of Violations for This Water System: 3</b>							
NV0004064	GOLDEN VALLEY PARK	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 10/31/2006		WASHOE
NV0004064	GOLDEN VALLEY PARK	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 09/30/2006		WASHOE
<b>Total Number of Violations for This Water System: 2</b>							
NV0000072	GOLDFIELD TOWN WATER	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 10/31/2006		ESMERALDA
<b>Total Number of Violations for This Water System: 1</b>							
NV0004037	HEYDAY INN	3100	COLIFORM, TOTAL (TCR)	22	01/01/2006 03/31/2006		LYON
<b>Total Number of Violations for This Water System: 1</b>							
NV0000961	HIDDEN CANYON RANCH	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		WHITE PINE
<b>Total Number of Violations for This Water System: 1</b>							
NV0000145	HILLCREST MANOR WATER USERS ASSOCIATION	3100	COLIFORM, TOTAL (TCR)	23	02/01/2006 02/28/2006		CLARK
<b>Total Number of Violations for This Water System: 1</b>							
NV0002046	HOLBROOK STATION RV AND MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	01/01/2006 03/31/2006		DOUGLAS

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002046	HOLBROOK STATION RV AND MHP	4010	RADIUM, COMBINED (226, 228)	03	01/01/2006 03/31/2006		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHP	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHP	4020	RADIUM-226	03	07/01/2006 09/30/2006		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHP	4020	RADIUM-226	03	01/01/2006 03/31/2006		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHP	4030	RADIUM-228	03	07/01/2006 09/30/2006		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHP	4030	RADIUM-228	03	01/01/2006 03/31/2006		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHP	4006	URANIUM, COMBINED	03	01/01/2006 03/31/2006		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHP	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		DOUGLAS
<b>Total Number of Violations for This Water System: 10</b>							
NV0003006	HOOVER DAM	2950	TOTAL TRIHALOMETHANES (TTHM)	02	10/01/2006 12/31/2006	7/25/2007	CLARK
<b>Total Number of Violations for This Water System: 1</b>							
NV0004073	IDLE SPURS LOUNGE AND RESTAURANT	3100	COLIFORM, TOTAL (TCR)	22	09/01/2006 09/30/2006		CLARK
NV0004073	IDLE SPURS LOUNGE AND RESTAURANT	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 10/31/2006		CLARK
<b>Total Number of Violations for This Water System: 2</b>							
NV0000226	IMLAY WATER SYSTEM	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		PERSHING
<b>Total Number of Violations for This Water System: 1</b>							
NV0000158	INCLINE VILLAGE GID	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000158	INCLINE VILLAGE GID	0200	SURFACE WATER TREATMENT RULE (SWTR)	41	06/01/2006 06/30/2006	7/20/2006	WASHOE
Total Number of Violations for This Water System: 2							
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	01/01/2006 01/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	09/01/2006 09/30/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	02/01/2006 02/28/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	03/01/2006 03/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	04/01/2006 04/30/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	08/01/2006 08/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	07/01/2006 07/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	05/01/2006 05/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	10/01/2006 10/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	12/01/2006 12/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	06/01/2006 06/30/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	0999	CHLORINE	27	11/01/2006 11/30/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	3100	COLIFORM, TOTAL (TCR)	22	08/01/2006 08/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 07/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	3100	COLIFORM, TOTAL (TCR)	22	05/01/2006 05/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CLARK
NV0000082	INDIAN SPRINGS WATER CO INC	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CLARK
Total Number of Violations for This Water System: 17							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002069	JACK CREEK LODGE	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		ELKO
Total Number of Violations for This Water System: 1							
NV0000088	JACKPOT WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	22	06/01/2006 06/30/2006	5/8/2007	ELKO
NV0000088	JACKPOT WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	22	05/01/2006 05/31/2006	5/8/2007	ELKO
NV0000088	JACKPOT WATER SYSTEM	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
NV0000088	JACKPOT WATER SYSTEM	4006	URANIUM, COMBINED	02	01/01/2006 12/31/2006		ELKO
Total Number of Violations for This Water System: 4							
NV0002070	JARBIDGE WATER SYSTEM	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
NV0002070	JARBIDGE WATER SYSTEM	5000	LEAD & COPPER RULE	51	01/01/2006 06/30/2006	4/19/2007	ELKO
Total Number of Violations for This Water System: 2							
NV0000906	JETWAY CHEVROLET	3100	COLIFORM, TOTAL (TCR)	22	01/01/2006 03/31/2006	2/26/2007	CHURCHILL
NV0000906	JETWAY CHEVROLET	5000	LEAD & COPPER RULE	52	01/01/2006 12/31/2006		CHURCHILL
NV0000906	JETWAY CHEVROLET	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CHURCHILL
Total Number of Violations for This Water System: 3							
NV0002071	JIGGS BAR	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		ELKO
NV0002071	JIGGS BAR	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		ELKO
Total Number of Violations for This Water System: 2							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000731	JOHNNYS LITTLE ITALY RESTAURANT	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 01/31/2006		WASHOE
Total Number of Violations for This Water System: 1							
NV0000886	JUST COUNTRY BAR	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		NYE
Total Number of Violations for This Water System: 1							
NV0000825	JWS DOUBLE TROUBLE	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		LYON
NV0000825	JWS DOUBLE TROUBLE	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		LYON
Total Number of Violations for This Water System: 2							
NV0000004	KINGSBURY GID	1011	BROMATE	27	02/01/2006 02/28/2006	1/12/2007	DOUGLAS
NV0000004	KINGSBURY GID	0200	SURFACE WATER TREATMENT RULE (SWTR)	42	07/27/2006 08/02/2006		DOUGLAS
Total Number of Violations for This Water System: 2							
NV0000265	KINGSTON TOWN WATER UTILITIES	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		LANDER
Total Number of Violations for This Water System: 1							
NV0002174	KOA OF ELY CAMPGROUND	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0002028	LAHONTAN DAM STATE PARK	3100	COLIFORM, TOTAL (TCR)	22	08/01/2006 08/31/2006		CHURCHILL
Total Number of Violations for This Water System: 1							
NV0000273	LAMOILLE WATER USERS ASSOC	3100	COLIFORM, TOTAL (TCR)	23	03/01/2006 03/31/2006		ELKO

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000273	LAMOILLE WATER USERS ASSOC	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
Total Number of Violations for This Water System: 2							
NV0000008	LANDER CO SEWER AND WATER DIST 1 BM	3100	COLIFORM, TOTAL (TCR)	22	05/01/2006 05/31/2006		LANDER
Total Number of Violations for This Water System: 1							
NV0004055	LANES TRAVEL CENTER	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		WHITE PINE
NV0004055	LANES TRAVEL CENTER	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WHITE PINE
Total Number of Violations for This Water System: 2							
NV0000307	LAS VEGAS SKI AND SNOWBOARD RESORT	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		CLARK
NV0000307	LAS VEGAS SKI AND SNOWBOARD RESORT	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006	8/1/2007	CLARK
Total Number of Violations for This Water System: 2							
NV0000341	LAST RESORT RESTAURANT	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		LYON
NV0000341	LAST RESORT RESTAURANT	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		LYON
NV0000341	LAST RESORT RESTAURANT	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006	6/1/2007	LYON
Total Number of Violations for This Water System: 3							
NV0000938	LATTIN FARMS	3100	COLIFORM, TOTAL (TCR)	25	07/01/2006 09/30/2006		CHURCHILL
Total Number of Violations for This Water System: 1							
NV0005068	LDS CHURCH PAHRUMP WARD	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0005068	LDS CHURCH PAHRUMP WARD	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		NYE
Total Number of Violations for This Water System: 2							
NV0000338	LEEVILLE POTABLE WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 12/31/2006		EUREKA
Total Number of Violations for This Water System: 1							
NV0000857	LINDAS WABUSKA BAR	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		LYON
NV0000857	LINDAS WABUSKA BAR	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		LYON
Total Number of Violations for This Water System: 2							
NV0002050	LOGAN CREEK ESTATES GID	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	01/01/2006 03/31/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4010	RADIUM, COMBINED (226, 228)	03	01/01/2006 03/31/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4020	RADIUM-226	03	04/01/2006 06/30/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4020	RADIUM-226	03	01/01/2006 03/31/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4030	RADIUM-228	03	01/01/2006 03/31/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4030	RADIUM-228	03	04/01/2006 06/30/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		DOUGLAS
NV0002050	LOGAN CREEK ESTATES GID	4006	URANIUM, COMBINED	03	01/01/2006 03/31/2006		DOUGLAS
Total Number of Violations for This Water System: 10							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0004096	LONE MOUNTAIN STATION	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		ELKO
Total Number of Violations for This Water System: 1							
NV0000861	LOVELOCK CORRECTIONAL CENTER NDOP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		PERSHING
Total Number of Violations for This Water System: 1							
NV0000979	LUND SCHOOL	2950	TOTAL TRIHALOMETHANES (TTHM)	27	01/01/2006 12/31/2006		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0002175	MAJORS STATION	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0000165	MANHATTAN TOWN WATER	1005	ARSENIC	02	01/01/2006 12/31/2006		NYE
NV0000165	MANHATTAN TOWN WATER	1005	ARSENIC	03	07/01/2006 09/30/2006		NYE
Total Number of Violations for This Water System: 2							
NV0000162	MCDERMITT WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 10/31/2006		HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0000163	MCGILL WATER AND SEWER DIST	0999	CHLORINE	27	03/01/2006 03/31/2006		WHITE PINE
NV0000163	MCGILL WATER AND SEWER DIST	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WHITE PINE
Total Number of Violations for This Water System: 2							
NV0002508	MCWILLIAMS WATER SYSTEM USFS	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CLARK
Total Number of Violations for This Water System: 1							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000757	MELS DINER	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 07/31/2006		WASHOE
Total Number of Violations for This Water System: 1							
NV0003071	MIDAS WATER COOPERATIVE	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 12/31/2006		ELKO
Total Number of Violations for This Water System: 1							
NV0000160	MOAPA VALLEY WATER DISTRICT	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 10/31/2006		CLARK
Total Number of Violations for This Water System: 1							
NV0001048	MOHAVE GENERATING STATION	0200	SURFACE WATER TREATMENT RULE (SWTR)	41	06/01/2006 06/30/2006	6/16/2006	CLARK
Total Number of Violations for This Water System: 1							
NV0000169	MONTELO WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	23	05/01/2006 05/31/2006		ELKO
NV0000169	MONTELO WATER SYSTEM	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
NV0000169	MONTELO WATER SYSTEM	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		ELKO
NV0000169	MONTELO WATER SYSTEM	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		ELKO
NV0000169	MONTELO WATER SYSTEM	4020	RADIUM-226	03	07/01/2006 09/30/2006		ELKO
NV0000169	MONTELO WATER SYSTEM	4030	RADIUM-228	03	07/01/2006 09/30/2006		ELKO
NV0000169	MONTELO WATER SYSTEM	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		ELKO
Total Number of Violations for This Water System: 7							
NV0000732	MOUNT ROSE BOWL HOMEOWNERS ASSOCIATION	0999	CHLORINE	27	09/01/2006 09/30/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000732	MOUNT ROSE BOWL HOMEOWNERS ASSOCIATION	3100	COLIFORM, TOTAL (TCR)	23	09/01/2006 09/30/2006		WASHOE
NV0000732	MOUNT ROSE BOWL HOMEOWNERS ASSOCIATION	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WASHOE
NV0000732	MOUNT ROSE BOWL HOMEOWNERS ASSOCIATION	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WASHOE
NV0000732	MOUNT ROSE BOWL HOMEOWNERS ASSOCIATION	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WASHOE
NV0000732	MOUNT ROSE BOWL HOMEOWNERS ASSOCIATION	2456	TOTAL HALOACETIC ACIDS (HAA5)	27	01/01/2006 12/31/2006		WASHOE
NV0000732	MOUNT ROSE BOWL HOMEOWNERS ASSOCIATION	2950	TOTAL TRIHALOMETHANES (TTHM)	27	01/01/2006 12/31/2006		WASHOE
<b>Total Number of Violations for This Water System: 7</b>							
NV0000170	MOUNTAIN CITY WATER SYSTEM	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
<b>Total Number of Violations for This Water System: 1</b>							
NV0001082	MOUNTAIN SPRINGS BAR INC	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CLARK
NV0001082	MOUNTAIN SPRINGS BAR INC	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		CLARK
<b>Total Number of Violations for This Water System: 2</b>							
NV0000037	NEVADA YOUTH TRAINING CENTER	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
<b>Total Number of Violations for This Water System: 1</b>							
NV0000874	NEW BEGINNINGS CHRISTIAN CHURCH	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		WASHOE
<b>Total Number of Violations for This Water System: 1</b>							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002600	NEWMONT GOLD GOLD QUARRY	3100	COLIFORM, TOTAL (TCR)	22	09/01/2006 09/30/2006		EUREKA
Total Number of Violations for This Water System: 1							
NV0000977	NORTH COUNTY WATER SYSTEM	5000	LEAD & COPPER RULE	52	01/01/2006 12/31/2006		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0003005	NPS BOULDER BEACH	5000	LEAD & COPPER RULE	51	07/01/2006 12/31/2006		CLARK
NV0003005	NPS BOULDER BEACH	2456	TOTAL HALOACETIC ACIDS (HAA5)	27	04/01/2006 06/30/2006	3/30/2007	CLARK
NV0003005	NPS BOULDER BEACH	2950	TOTAL TRIHALOMETHANES (TTHM)	27	04/01/2006 06/30/2006	3/30/2007	CLARK
Total Number of Violations for This Water System: 3							
NV0002506	NPS CALLVILLE BAY	2950	TOTAL TRIHALOMETHANES (TTHM)	02	04/01/2006 06/30/2006		CLARK
NV0002506	NPS CALLVILLE BAY	2950	TOTAL TRIHALOMETHANES (TTHM)	02	07/01/2006 09/30/2006		CLARK
NV0002506	NPS CALLVILLE BAY	2950	TOTAL TRIHALOMETHANES (TTHM)	02	01/01/2006 03/31/2006		CLARK
NV0002506	NPS CALLVILLE BAY	2950	TOTAL TRIHALOMETHANES (TTHM)	02	10/01/2006 12/31/2006		CLARK
Total Number of Violations for This Water System: 4							
NV0000051	OASIS MHP	0999	CHLORINE	27	01/01/2006 01/31/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	03/01/2006 03/31/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	09/01/2006 09/30/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	04/01/2006 04/30/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	12/01/2006 12/31/2006		CHURCHILL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000051	OASIS MHP	0999	CHLORINE	27	02/01/2006 02/28/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	10/01/2006 10/31/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	07/01/2006 07/31/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	08/01/2006 08/31/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	06/01/2006 06/30/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	11/01/2006 11/30/2006		CHURCHILL
NV0000051	OASIS MHP	0999	CHLORINE	27	05/01/2006 05/31/2006		CHURCHILL
NV0004017	OASIS MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
NV0000051	OASIS MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL
NV0000051	OASIS MHP	2456	TOTAL HALOACETIC ACIDS (HAA5)	27	01/01/2006 12/31/2006		CHURCHILL
NV0000051	OASIS MHP	2950	TOTAL TRIHALOMETHANES (TTHM)	27	01/01/2006 12/31/2006		CHURCHILL
<b>Total Number of Violations for This Water System: 16</b>							
NV0000921	OASIS SPRINGS	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		CHURCHILL
NV0000921	OASIS SPRINGS	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CHURCHILL
<b>Total Number of Violations for This Water System: 2</b>							
NV0003032	OROVADA WATER DISTRICT	3100	COLIFORM, TOTAL (TCR)	21	01/01/2006 01/31/2006		HUMBOLDT
NV0003032	OROVADA WATER DISTRICT	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 07/31/2006		HUMBOLDT
NV0003032	OROVADA WATER DISTRICT	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		HUMBOLDT
NV0003032	OROVADA WATER DISTRICT	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		HUMBOLDT

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
<b>Total Number of Violations for This Water System: 4</b>							
NV0000183	PAHRUMP MHP	3100	COLIFORM, TOTAL (TCR)	22	09/01/2006 09/30/2006		NYE
NV0000183	PAHRUMP MHP	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 04/30/2006		NYE
NV0000183	PAHRUMP MHP	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 07/31/2006		NYE
NV0000183	PAHRUMP MHP	3100	COLIFORM, TOTAL (TCR)	23	08/01/2006 08/31/2006		NYE
NV0000183	PAHRUMP MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		NYE
<b>Total Number of Violations for This Water System: 5</b>							
NV0003036	PAHRUMP SENIOR CENTER INC	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		NYE
<b>Total Number of Violations for This Water System: 1</b>							
NV0000819	PALM GARDENS WATER CO OP	3100	COLIFORM, TOTAL (TCR)	23	09/01/2006 09/30/2006		CLARK
NV0000819	PALM GARDENS WATER CO OP	3100	COLIFORM, TOTAL (TCR)	23	03/01/2006 03/31/2006		CLARK
NV0000819	PALM GARDENS WATER CO OP	3100	COLIFORM, TOTAL (TCR)	23	02/01/2006 02/28/2006		CLARK
NV0000819	PALM GARDENS WATER CO OP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CLARK
<b>Total Number of Violations for This Water System: 4</b>							
NV0000131	PALOMINO WATER ASSOCIATION	0999	CHLORINE	27	04/01/2006 04/30/2006		CLARK
NV0000131	PALOMINO WATER ASSOCIATION	0999	CHLORINE	27	05/01/2006 05/31/2006		CLARK
<b>Total Number of Violations for This Water System: 2</b>							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000205	PANTHER VALLEY WATER COMPANY	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WASHOE
Total Number of Violations for This Water System: 1							
NV0002186	PARADISE VALLEY ELEMENTARY	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 01/31/2006		HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0000849	PINE GROVE UTILITY TRUST	0999	CHLORINE	27	06/01/2006 06/30/2006	6/12/2007	CHURCHILL
NV0000849	PINE GROVE UTILITY TRUST	0999	CHLORINE	27	02/01/2006 02/28/2006	6/12/2007	CHURCHILL
NV0000849	PINE GROVE UTILITY TRUST	0999	CHLORINE	27	04/01/2006 04/30/2006	6/12/2007	CHURCHILL
NV0000849	PINE GROVE UTILITY TRUST	0999	CHLORINE	27	01/01/2006 01/31/2006	6/12/2007	CHURCHILL
NV0000849	PINE GROVE UTILITY TRUST	0999	CHLORINE	27	03/01/2006 03/31/2006	6/12/2007	CHURCHILL
NV0000849	PINE GROVE UTILITY TRUST	0999	CHLORINE	27	05/01/2006 05/31/2006	6/12/2007	CHURCHILL
Total Number of Violations for This Water System: 6							
NV0000067	PINION PINES MHP	3100	COLIFORM, TOTAL (TCR)	22	01/01/2006 01/31/2006		DOUGLAS
NV0000067	PINION PINES MHP	3100	COLIFORM, TOTAL (TCR)	22	05/01/2006 05/31/2006	8/6/2007	DOUGLAS
NV0000067	PINION PINES MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		DOUGLAS
Total Number of Violations for This Water System: 3							
NV0000187	PIOCHE PUBLIC UTILITIES CASTLETON	3100	COLIFORM, TOTAL (TCR)	22	11/01/2006 11/30/2006		LINCOLN
Total Number of Violations for This Water System: 1							
NV0000206	PIONEER HILLS MHP	1074	ANTIMONY	02	01/01/2006 03/31/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000206	PIONEER HILLS MHP	1074	ANTIMONY	02	01/01/2006 03/31/2006		WASHOE
NV0000206	PIONEER HILLS MHP	1074	ANTIMONY	02	04/01/2006 06/30/2006		WASHOE
NV0000206	PIONEER HILLS MHP	1074	ANTIMONY	02	04/01/2006 06/30/2006		WASHOE
NV0000206	PIONEER HILLS MHP	1074	ANTIMONY	02	07/01/2006 09/30/2006		WASHOE
NV0000206	PIONEER HILLS MHP	1074	ANTIMONY	02	10/01/2006 12/31/2006		WASHOE
NV0000206	PIONEER HILLS MHP	1074	ANTIMONY	02	10/01/2006 12/31/2006		WASHOE
<b>Total Number of Violations for This Water System: 7</b>							
NV0000388	PLAYMATE RANCH	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 07/31/2006		MINERAL
NV0000388	PLAYMATE RANCH	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		MINERAL
NV0000388	PLAYMATE RANCH	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		MINERAL
<b>Total Number of Violations for This Water System: 3</b>							
NV0000750	PLEASANT VALLEY SCHOOL	3100	COLIFORM, TOTAL (TCR)	22	06/01/2006 06/30/2006	1/5/2006	WASHOE
NV0000750	PLEASANT VALLEY SCHOOL	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 07/31/2006		WASHOE
<b>Total Number of Violations for This Water System: 2</b>							
NV0002119	R PLACE LITTLE ASH SPRINGS	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		LINCOLN
<b>Total Number of Violations for This Water System: 1</b>							
NV0001069	RANCH HOUSE	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		CLARK
<b>Total Number of Violations for This Water System: 1</b>							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000349	RODEO CREEK GOLD INC	0999	CHLORINE	27	11/01/2006 11/30/2006		ELKO
NV0000349	RODEO CREEK GOLD INC	0999	CHLORINE	27	12/01/2006 12/31/2006		ELKO
NV0000349	RODEO CREEK GOLD INC	3100	COLIFORM, TOTAL (TCR)	22	10/01/2006 12/31/2006		ELKO
Total Number of Violations for This Water System: 3							
NV0000260	ROUND HILL GID	1052	SODIUM	03	01/01/2006 12/31/2006		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0002542	ROYAL PEACOCK RV PARK	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0000904	RUBY LAKE RESORT	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		ELKO
NV0000904	RUBY LAKE RESORT	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		ELKO
Total Number of Violations for This Water System: 2							
NV0000164	RUTH WATER DISTRICT	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0002075	RYNDON CAMPGROUND WATER SYSTEM	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		ELKO
Total Number of Violations for This Water System: 1							
NV0000231	SAGE TRAILER PARK	1005	ARSENIC	03	07/01/2006 09/30/2006		WASHOE
NV0000231	SAGE TRAILER PARK	1005	ARSENIC	03	04/01/2006 06/30/2006		WASHOE
NV0000231	SAGE TRAILER PARK	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000231	SAGE TRAILER PARK	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	01/01/2006 03/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	1040	NITRATE (AS N)	03	04/01/2006 06/30/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4010	RADIUM, COMBINED (226, 228)	03	01/01/2006 03/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4020	RADIUM-226	03	04/01/2006 06/30/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4020	RADIUM-226	03	10/01/2006 12/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4020	RADIUM-226	03	01/01/2006 03/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4030	RADIUM-228	03	04/01/2006 06/30/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4030	RADIUM-228	03	01/01/2006 03/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4030	RADIUM-228	03	10/01/2006 12/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4006	URANIUM, COMBINED	03	01/01/2006 03/31/2006		WASHOE
NV0000231	SAGE TRAILER PARK	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		WASHOE
Total Number of Violations for This Water System:		19					
NV0000203	SAGE VALLEY MHP	3100	COLIFORM, TOTAL (TCR)	23	09/01/2006 09/30/2006		CHURCHILL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002023	SAGE VALLEY MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL
NV0002023	SAGE VALLEY MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		CHURCHILL
NV0002023	SAGE VALLEY MHP	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		CHURCHILL
NV0002023	SAGE VALLEY MHP	4020	RADIUM-226	03	07/01/2006 09/30/2006		CHURCHILL
NV0002023	SAGE VALLEY MHP	4030	RADIUM-228	03	07/01/2006 09/30/2006		CHURCHILL
NV0002023	SAGE VALLEY MHP	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		CHURCHILL
<b>Total Number of Violations for This Water System: 7</b>							
NV0000306	SANDWINDS RESTAURANT SPORTS BAR	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CHURCHILL
<b>Total Number of Violations for This Water System: 1</b>							
NV0004001	SANDY VALLEY ELEMENTARY SCHOOL	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CLARK
<b>Total Number of Violations for This Water System: 1</b>							
NV0000358	SCHELLBOURNE STATION	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		WHITE PINE
NV0000358	SCHELLBOURNE STATION	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		WHITE PINE
NV0000358	SCHELLBOURNE STATION	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		WHITE PINE
<b>Total Number of Violations for This Water System: 3</b>							
NV0000219	SEARCHLIGHT WATER COMPANY	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CLARK
<b>Total Number of Violations for This Water System: 1</b>							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000126	SHETLAND WATER DISTRICT	3100	COLIFORM, TOTAL (TCR)	22	08/01/2006 08/31/2006		CLARK
NV0000126	SHETLAND WATER DISTRICT	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CLARK
Total Number of Violations for This Water System: 2							
NV0003074	SHORT BRANCH	3100	COLIFORM, TOTAL (TCR)	25	07/01/2006 09/30/2006		NYE
Total Number of Violations for This Water System: 1							
NV0005028	SHOSHONE ESTATES WATER COMPANY	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		NYE
Total Number of Violations for This Water System: 1							
NV0000030	SIERRA ESTATES GID	3100	COLIFORM, TOTAL (TCR)	25	11/01/2006 11/30/2006		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0000363	SILVER PEAK WATER SYSTEM	4006	URANIUM, COMBINED	02	01/01/2006 12/31/2006		ESMERALDA
Total Number of Violations for This Water System: 1							
NV0002595	SILVER SPRINGS CONSERVATION CAMP NDOP	1005	ARSENIC	03	10/01/2006 12/31/2006		LYON
NV0002595	SILVER SPRINGS CONSERVATION CAMP NDOP	1005	ARSENIC	03	07/01/2006 09/30/2006		LYON
Total Number of Violations for This Water System: 2							
NV0000267	SILVER SPRINGS MHP	1040	NITRATE (AS N)	03	07/01/2006 09/30/2006		LYON
Total Number of Violations for This Water System: 1							
NV0002581	SKIPS MINI MARKET	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		CHURCHILL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002581	SKIPS MINI MARKET	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CHURCHILL
Total Number of Violations for This Water System: 2							
NV0000760	SKY TAVERN	3100	COLIFORM, TOTAL (TCR)	22	06/01/2006 06/30/2006		WASHOE
NV0000760	SKY TAVERN	3100	COLIFORM, TOTAL (TCR)	22	05/01/2006 05/31/2006		WASHOE
NV0000760	SKY TAVERN	3100	COLIFORM, TOTAL (TCR)	23	08/01/2006 08/31/2006		WASHOE
Total Number of Violations for This Water System: 3							
NV0000929	SONIC BURGER	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CHURCHILL
Total Number of Violations for This Water System: 1							
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2981	1,1,1-TRICHLOROETHANE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2985	1,1,2-TRICHLOROETHANE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2977	1,1-DICHLOROETHYLENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2378	1,2,4-TRICHLOROBENZENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2980	1,2-DICHLOROETHANE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2983	1,2-DICHLOROPROPANE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2990	BENZENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2982	CARBON TETRACHLORIDE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2380	CIS-1,2-DICHLOROETHYLENE	03	10/01/2006 12/31/2006		ELKO

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2964	DICHLOROMETHANE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2992	ETHYLBENZENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2989	MONOCHLOROBENZENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2968	O-DICHLOROBENZENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2969	P-DICHLOROBENZENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2996	STYRENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2987	TETRACHLOROETHYLENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2991	TOLUENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2979	TRANS-1,2-DICHLOROETHYLENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2984	TRICHLOROETHYLENE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2976	VINYL CHLORIDE	03	10/01/2006 12/31/2006		ELKO
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	2955	XYLENES	03	10/01/2006 12/31/2006		ELKO
Total Number of Violations for This Water System:		21					
NV0000055	SOUTH MAINE MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL
NV0000055	SOUTH MAINE MHP	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CHURCHILL
NV0000055	SOUTH MAINE MHP	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CHURCHILL
NV0000055	SOUTH MAINE MHP	4006	URANIUM, COMBINED	02	01/01/2006 12/31/2006		CHURCHILL
Total Number of Violations for This Water System:		4					

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CLARK
Total Number of Violations for This Water System: 1							
NV0000221	SPIRIT MOUNTAIN UTILITY	3100	COLIFORM, TOTAL (TCR)	23	02/01/2006 02/28/2006		CLARK
Total Number of Violations for This Water System: 1							
NV0005027	SPRING CREEK MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
Total Number of Violations for This Water System: 1							
NV0002178	STAGE STOP CAFE	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0002608	STAGECOACH BAR GRILL AND LIQUORS	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		LYON
Total Number of Violations for This Water System: 1							
NV0004040	STAGECOACH MARKET	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006	6/27/2007	LYON
Total Number of Violations for This Water System: 1							
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	3100	COLIFORM, TOTAL (TCR)	23	02/01/2006 02/28/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	01/01/2006 03/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	01/01/2006 03/31/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4010	RADIUM, COMBINED (226, 228)	03	01/01/2006 03/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4010	RADIUM, COMBINED (226, 228)	03	01/01/2006 03/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4020	RADIUM-226	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4020	RADIUM-226	03	04/01/2006 06/30/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4020	RADIUM-226	03	01/01/2006 03/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4020	RADIUM-226	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4020	RADIUM-226	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4020	RADIUM-226	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4020	RADIUM-226	03	01/01/2006 03/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4020	RADIUM-226	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4030	RADIUM-228	03	01/01/2006 03/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4030	RADIUM-228	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4030	RADIUM-228	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4030	RADIUM-228	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4030	RADIUM-228	03	01/01/2006 03/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4030	RADIUM-228	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4030	RADIUM-228	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4030	RADIUM-228	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4006	URANIUM, COMBINED	03	04/01/2006 06/30/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4006	URANIUM, COMBINED	03	01/01/2006 03/31/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4006	URANIUM, COMBINED	03	01/01/2006 03/31/2006		WASHOE
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		WASHOE
Total Number of Violations for This Water System: 43							
NV0000123	SUNRISE MOUNTAIN TP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CLARK
Total Number of Violations for This Water System: 1							
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2981	1,1,1- TRICHLOROETHANE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2985	1,1,2- TRICHLOROETHANE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2977	1,1- DICHLOROETHYLENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2378	1,2,4- TRICHLOROBENZENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2980	1,2- DICHLOROETHANE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2983	1,2- DICHLOROPROPANE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2110	2,4,5-TP (SILVEX)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2105	2,4-D	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2051	ALACHLOR (LASSO)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2047	ALDICARB	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2044	ALDICARB SULFONE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2043	ALDICARB SULFOXIDE	03	10/01/2006 12/31/2006		STOREY

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2388	AROCLOR 1016 (PCB)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2390	AROCLOR 1221 (PCB)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2392	AROCLOR 1232 (PCB)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2394	AROCLOR 1242 (PCB)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2396	AROCLOR 1248 (PCB)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2398	AROCLOR 1254 (PCB)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2400	AROCLOR 1260 (PCB)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2050	ATRAZINE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2990	BENZENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2306	BENZO (A) PYRENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2010	BHC-GAMMA (LINDANE)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2046	CARBOFURAN	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2982	CARBON TETRACHLORIDE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2959	CHLORDANE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2380	CIS-1,2- DICHLOROETHYLENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2031	DALAPON	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2035	DI(2-ETHYLHEXYL) - ADIPATE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2039	DI(2-ETHYLHEXYL) - PHTHALATE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2931	DIBROMOCHLOROPROPANE (DBCP)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2964	DICHLOROMETHANE	03	10/01/2006 12/31/2006		STOREY

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2041	DINOSEB	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2032	DIQUAT	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2033	ENDOTHALL	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2005	ENDRIN	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2992	ETHYLBENZENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2946	ETHYLENE DIBROMIDE (EDB)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2034	GLYPHOSATE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2065	HEPTACHLOR	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2067	HEPTACHLOR EPOXIDE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2274	HEXACHLOROBENZENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2042	HEXACHLOROCYCLOPENTADIE NE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2015	METHOXYCHLOR	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2989	MONOCHLOROBENZENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2968	O- DICHLOROBENZENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2036	OXAMYL (VYDATE)	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2969	P- DICHLOROBENZENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2326	PENTACHLOROPHENOL	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2040	PICLORAM	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2037	SIMAZINE	03	10/01/2006 12/31/2006		STOREY

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2996	STYRENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2987	TETRACHLOROETHYLENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2991	TOLUENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2020	TOXAPHENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2979	TRANS-1,2-DICHLOROETHYLENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2984	TRICHLOROETHYLENE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2976	VINYL CHLORIDE	03	10/01/2006 12/31/2006		STOREY
NV0000913	TAHOE RENO INDUSTRIAL CENTER	2955	XYLENES	03	10/01/2006 12/31/2006		STOREY
Total Number of Violations for This Water System: 59							
NV0002076	TAYLOR CANYON CLUB	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		ELKO
NV0002076	TAYLOR CANYON CLUB	3100	COLIFORM, TOTAL (TCR)	23	10/01/2006 12/31/2006		ELKO
Total Number of Violations for This Water System: 2							
NV0000028	TERRACE GARDEN APARTMENTS	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CARSON CITY
Total Number of Violations for This Water System: 1							
NV0004076	THE LODGE AT GALENA	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		WASHOE
Total Number of Violations for This Water System: 1							
NV0000914	THE PATIO CAFE	1040	NITRATE (AS N)	01	01/01/2006 12/31/2006	9/29/2006	NYE
NV0000914	THE PATIO CAFE	1040	NITRATE (AS N)	04	01/01/2006 01/31/2006	9/29/2006	NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
<b>Total Number of Violations for This Water System: 2</b>							
NV0000214	THREE T WATER COMPANY	0999	CHLORINE	27	02/01/2006 02/28/2006		WASHOE
NV0000214	THREE T WATER COMPANY	3100	COLIFORM, TOTAL (TCR)	21	01/01/2006 01/31/2006		WASHOE
<b>Total Number of Violations for This Water System: 2</b>							
NV0000061	TOLAS PARK MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL
<b>Total Number of Violations for This Water System: 1</b>							
NV0002518	TOPAZ LIQUOR MART	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		DOUGLAS
<b>Total Number of Violations for This Water System: 1</b>							
NV0000168	TOWN OF MINDEN	3100	COLIFORM, TOTAL (TCR)	23	12/01/2006 12/31/2006	5/10/2007	DOUGLAS
<b>Total Number of Violations for This Water System: 1</b>							
NV0000331	TRAILS END GENERAL STORE	3100	COLIFORM, TOTAL (TCR)	22	06/01/2006 06/30/2006		CLARK
<b>Total Number of Violations for This Water System: 1</b>							
NV0002159	TRAVEL CENTERS OF AMERICA NO 181	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 07/31/2006		PERSHING
<b>Total Number of Violations for This Water System: 1</b>							
NV0001059	TROPICANA HOTEL	3100	COLIFORM, TOTAL (TCR)	22	09/01/2006 09/30/2006		CLARK
NV0001059	TROPICANA HOTEL	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CLARK
<b>Total Number of Violations for This Water System: 2</b>							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000373	TROUT CANYON WATER COMPANY	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		CLARK
Total Number of Violations for This Water System: 1							
NV0000827	TUMBLEWEED TAVERN	3100	COLIFORM, TOTAL (TCR)	23	11/01/2006 11/30/2006		NYE
Total Number of Violations for This Water System: 1							
NV0000189	TUSCARORA WATER SYSTEM	3100	COLIFORM, TOTAL (TCR)	21	12/01/2006 12/31/2006		ELKO
NV0000189	TUSCARORA WATER SYSTEM	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
NV0000189	TUSCARORA WATER SYSTEM	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		ELKO
NV0000189	TUSCARORA WATER SYSTEM	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		ELKO
NV0000189	TUSCARORA WATER SYSTEM	4020	RADIUM-226	03	07/01/2006 09/30/2006		ELKO
NV0000189	TUSCARORA WATER SYSTEM	4030	RADIUM-228	03	07/01/2006 09/30/2006		ELKO
NV0000189	TUSCARORA WATER SYSTEM	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		ELKO
Total Number of Violations for This Water System: 7							
NV0002112	VALMY STATION	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0003016	VALMY STATION MOBILE HOME PARK	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0000167	VIRGIN VALLEY WATER DISTRICT	1025	FLUORIDE	03	01/01/2006 03/31/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000167	VIRGIN VALLEY WATER DISTRICT	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4010	RADIUM, COMBINED (226, 228)	03	04/01/2006 06/30/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4020	RADIUM-226	03	04/01/2006 06/30/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4020	RADIUM-226	03	07/01/2006 09/30/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4020	RADIUM-226	03	10/01/2006 12/31/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4030	RADIUM-228	03	04/01/2006 06/30/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4030	RADIUM-228	03	10/01/2006 12/31/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4030	RADIUM-228	03	07/01/2006 09/30/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		CLARK
NV0000167	VIRGIN VALLEY WATER DISTRICT	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		CLARK
Total Number of Violations for This Water System:		16					
NV0000960	WADSWORTH INN	3100	COLIFORM, TOTAL (TCR)	23	02/01/2006 02/28/2006		WASHOE
Total Number of Violations for This Water System:		1					
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	10/01/2006 10/31/2006		WASHOE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	11/01/2006 11/30/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	09/01/2006 09/30/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	01/01/2006 01/31/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	08/01/2006 08/31/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	05/01/2006 05/31/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	02/01/2006 02/28/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	03/01/2006 03/31/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	0999	CHLORINE	27	04/01/2006 04/30/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 01/31/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	2456	TOTAL HALOACETIC ACIDS (HAA5)	27	01/01/2006 12/31/2006		WASHOE
NV0000281	WADSWORTH MOBILE HOME PARK	2950	TOTAL TRIHALOMETHANES (THM)	27	01/01/2006 12/31/2006		WASHOE
Total Number of Violations for This Water System:		12					
NV0002037	WAGON WHEEL BAR	3100	COLIFORM, TOTAL (TCR)	23	04/01/2006 06/30/2006		CHURCHILL
Total Number of Violations for This Water System:		1					
NV0000302	WALKER LAKE APARTMENTS	3100	COLIFORM, TOTAL (TCR)	23	06/01/2006 06/30/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	07/01/2006 09/30/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		MINERAL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000302	WALKER LAKE APARTMENTS	4010	RADIUM, COMBINED (226, 228)	03	07/01/2006 09/30/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	4020	RADIUM-226	03	07/01/2006 09/30/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	4020	RADIUM-226	03	10/01/2006 12/31/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	4030	RADIUM-228	03	07/01/2006 09/30/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		MINERAL
NV0000302	WALKER LAKE APARTMENTS	4006	URANIUM, COMBINED	03	07/01/2006 09/30/2006		MINERAL
Total Number of Violations for This Water System:		12					
NV0000268	WALKER LAKE GID	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		MINERAL
Total Number of Violations for This Water System:		1					
NV0004048	WALKER RIVER RESORT	3100	COLIFORM, TOTAL (TCR)	25	04/01/2006 06/30/2006		LYON
NV0004048	WALKER RIVER RESORT	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		LYON
Total Number of Violations for This Water System:		2					
NV0000727	WASHOE GRILL	3100	COLIFORM, TOTAL (TCR)	23	11/01/2006 11/30/2006		WASHOE
Total Number of Violations for This Water System:		1					
NV0000793	WASHOE LAKE STATE PARK	3100	COLIFORM, TOTAL (TCR)	22	09/01/2006 09/30/2006		WASHOE
NV0000793	WASHOE LAKE STATE PARK	3100	COLIFORM, TOTAL (TCR)	23	11/01/2006 11/30/2006		WASHOE
Total Number of Violations for This Water System:		2					

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT RAMP	3100	COLIFORM, TOTAL (TCR)	23	11/01/2006 11/30/2006		WASHOE
Total Number of Violations for This Water System: 1							
NV0000242	WEED HEIGHTS DEVELOPMENT	3100	COLIFORM, TOTAL (TCR)	23	12/01/2006 12/31/2006		LYON
Total Number of Violations for This Water System: 1							
NV0000376	WELLINGTON DELI AND SWEETWATER COFFEE	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 09/30/2006		LYON
Total Number of Violations for This Water System: 1							
NV0000245	WELLS MUNICIPAL WATER DEPARTMENT	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		ELKO
Total Number of Violations for This Water System: 1							
NV0000060	WEST STAR MHP	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL
NV0000060	WEST STAR MHP	4002	GROSS ALPHA, INCLDNG RA & U, EXCLDNG RN	03	10/01/2006 12/31/2006		CHURCHILL
NV0000060	WEST STAR MHP	5000	LEAD & COPPER RULE	51	01/01/2006 06/30/2006	6/28/2007	CHURCHILL
NV0000060	WEST STAR MHP	5000	LEAD & COPPER RULE	51	07/01/2006 12/31/2006	6/28/2007	CHURCHILL
NV0000060	WEST STAR MHP	4010	RADIUM, COMBINED (226, 228)	03	10/01/2006 12/31/2006		CHURCHILL
NV0000060	WEST STAR MHP	4020	RADIUM-226	03	10/01/2006 12/31/2006		CHURCHILL
NV0000060	WEST STAR MHP	4030	RADIUM-228	03	10/01/2006 12/31/2006		CHURCHILL
NV0000060	WEST STAR MHP	4006	URANIUM, COMBINED	03	10/01/2006 12/31/2006		CHURCHILL
Total Number of Violations for This Water System: 8							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002564	WEST VALLEY/ MONTANA	0999	CHLORINE	27	11/01/2006 11/30/2006		DOUGLAS
NV0002564	WEST VALLEY/ MONTANA	0999	CHLORINE	27	10/01/2006 10/31/2006		DOUGLAS
NV0002564	WEST VALLEY/ MONTANA	0999	CHLORINE	27	12/01/2006 12/31/2006		DOUGLAS
<b>Total Number of Violations for This Water System: 3</b>							
NV0000058	WILDES MANOR	7000	CONSUMER CONFIDENCE REPORTS RULE	71	01/01/2006 06/30/2006		CHURCHILL
NV0000058	WILDES MANOR	1040	NITRATE (AS N)	03	01/01/2006 12/31/2006		CHURCHILL
<b>Total Number of Violations for This Water System: 2</b>							
NV0000881	WILDHORSE BAR AND GRILL	3100	COLIFORM, TOTAL (TCR)	23	07/01/2006 09/30/2006		LYON
NV0000881	WILDHORSE BAR AND GRILL	3100	COLIFORM, TOTAL (TCR)	23	01/01/2006 03/31/2006		LYON
<b>Total Number of Violations for This Water System: 2</b>							
NV0000255	YERINGTON CITY OF	3100	COLIFORM, TOTAL (TCR)	22	07/01/2006 07/31/2006		LYON
<b>Total Number of Violations for This Water System: 1</b>							
NV0000258	ZEPHYR COVE WATER UTILITY DISTR	1011	BROMATE	27	03/01/2006 03/31/2006		DOUGLAS
<b>Total Number of Violations for This Water System: 1</b>							
<b>Total Number of Water Systems with one or more Violations for selected reporting interval:</b>				<b>231</b>			
<b>Total Number Violations for all Water Systems for selected reporting interval:</b>				<b>846</b>			

**Attachment A**  
**RULE-SPECIFIC VIOLATION CRITERIA**  
**FOR THE**  
**ANNUAL PUBLIC WATER SYSTEMS COMPLIANCE REPORT<sup>1</sup>**

**Chemical Contaminant Group Maximum Contaminant Level (MCL)**

MCL - Single Sample or MCL Average (Violation Types 01 and 02).

Only Community Water Systems can have an MCL for the following contaminant codes: 1025, 4000, 4010, and 4100.

Both Community and Non-transient Non-community (NTNC) water systems can have an MCL for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 1005, 1094, 1010, 1015, 1020, 1035, 1045, 1074, 1075, 1024, 1085.

All systems can have an MCL for Nitrate (contaminant codes 1038, 1040, and 1041).

**Chemical Contaminant Group Monitoring and Reporting (M/R)**

M/R - Monitoring, Regular (Violation Types 03 and 04 and Major Indicator Flag = Y).

Only Community Water Systems can have a M/R for the following contaminant codes: 1025, 4000, 4010, and 4100.

Both Community and NTNC water systems can have an M/R for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 2950, 2456, 0999, 1005, 1094, 1010, 1015, 1020, 1035, 1045, 1074, 1075, 1024, 1085.

---

<sup>1</sup> For violations that extend beyond the calendar year, the violation is counted in each of the calendar years in which it occurred, unless it has returned to compliance prior to the beginning of the calendar year.

All systems can have an M/R for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Treatment Technique (TT)

Both Community and NTNC water systems can have a TT violation for Acrylamide and Epichlorohydrine (Violation type 07, contaminant codes 2265 and 2257).

**Total Coliform Rule (TCR) MCLs**

Any violation that is either Acute or Monthly (Violation types 21 and 22). The contaminant code for TCR is 3100.

TCR Significant M/R

Any major Routine or Repeat M/R violation (Violation types 23 and 25). The contaminant code for TCR is 3100.

Surface Water Treatment Rule (SWTR) TT

Any TT violation for a filtered system (Violation type 41) and all unfiltered systems who are required to install filtration if at some point during the calendar year they were unfiltered. (Violation type 42 violations - these may not be in your state data systems). The contaminant code for SWTR is 0200.

SWTR Significant M/R

Any Significant surface water M/R violation by a filtered or unfiltered system (Violation Types 36 and 31 and Major Indicator Flag = Y, respectively). The contaminant code for SWTR is 0200.

Turbidity MCL

Any MCL Average violation for an unfiltered system (Violation type 02). The contaminant code for turbidity is 0100.

Turbidity Significant M/R

Any major regular M/R violation for an unfiltered system (Violation type 03 and Major Indicator Flag = Y). The contaminant code for turbidity is 0100.

Lead and Copper Rule (LCR) TT

Any Community or NTNC water system with a TT violation at any time during the calendar year (Violation Types 58, 62 and 65). Note: Violation type 62 has been combined under Violation type 58 in SDWIS.

#### LCR Significant M/R

Any Community or NTNC water system with a follow-up or routine tap sampling violation (Violation type 52) or any Community or NTNC water system who incurred an initial tap monitoring violation (Violation type 51) during the calendar year, or who incurred the initial tap violation prior to the calendar but failed to return to compliance prior to January 1 of the calendar year. Note: a system cannot have more than one initial tap monitoring violation counted in a calendar year.

In general: Count all violations above where any date in the violation compliance period begin and end date range falls within the calendar year **except** those that returned to compliance prior to the first day of the calendar year regardless of current system status.

Note: EPA has changed the state submitted compliance period end date of Violation types 51, 58, 62 and 65 to reflect either the date the violation returned to compliance or the date of 12/31/2015.

#### Consumer Confidence Report Rule (CCR) Significant Consumer Notification Violations and Public Notification Violations

Any Community water system that completely failed to provide a required consumer confidence report is in violation (Violation type 71). Because the violation continues until the system provides the report, the violation must also be reported in each subsequent year until the system returns to compliance. Public Notification violations are Violation type codes 75 for NPDWR and 76 for other potential health risk situations PN Violation (Non-NPDWR). For the Public Notice Violations the violation must be linked to a specific rule. The contaminant code for IESWTR is 0300. The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999.

#### Interim Enhanced Surface Water Treatment Rule (IESWTR) TT

Any public water system that uses surface water or ground water under the direct influence of surface water (GWUDI) and serving at least 10,000 people with a TT violation (Violations 37, 43, 44, and 47). The contaminant code for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001) <http://www.epa.gov/safewater/mbdp/ieswtrimplguid.pdf> for additional information

#### IESWTR Significant Recordkeeping and M/R Violations

Any public water system that uses surface water or GWUDI and serving at least 10,000 people with a M/R violation (Violation 29 and Violation 38 and Major Indicator Flag = Y). The contaminant code for IESWTR is 0300. Any recordkeeping violation where system fails to maintain the results of individual filter monitoring for 3 years. Violation type is 09. The contaminant code is for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001) <http://www.epa.gov/safewater/mbdp/ieswtrimplguid.pdf> for additional information

#### Filter Backwash Recycle Rule (FBRR) TT

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code is 40. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule [www.epa.gov/safewater/mbdp/guide\\_fbrr\\_ig\\_fnl\\_06-16-04.pdf](http://www.epa.gov/safewater/mbdp/guide_fbrr_ig_fnl_06-16-04.pdf) [EPA 816-R-04-006, June 2004] for additional information.

#### Filter Backwash Recycle Rule (FBRR) M/R and Recordkeeping

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code for M/R is 39 and for recordkeeping is 09. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule (EPA 816-R-04-006, June 2004) [www.epa.gov/safewater/mbdp/guide\\_fbrr\\_ig\\_fnl\\_06-16-04.pdf](http://www.epa.gov/safewater/mbdp/guide_fbrr_ig_fnl_06-16-04.pdf) for additional information.

#### Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) TT

Public water systems that use surface water or GWUDI and serve fewer than 10,000 people. The violation codes are 37 and 47. Like the IESWTR The contaminant code for LT1ESTR the contaminant code is 0300. See Section V of the Long Term Enhanced Surface Water **Treatment** Rule (LT1ESWTR) Implementation Guide for additional information at the website: [www.epa.gov/safewater/mbdp/pdfs/lt1eswtr/guidance\\_lt1\\_ig.pdf](http://www.epa.gov/safewater/mbdp/pdfs/lt1eswtr/guidance_lt1_ig.pdf)

#### Stage 1 Disinfectants and Disinfection Byproducts Rule (Stage 1 DBPR) TT

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with TT violations (Violations 12, 37 and 46). The contaminant codes for Stage 1 DBPR are 0400 and 2920. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mbdp/s1dbprimplguid.pdf> for additional information

#### Stage 1 DBPR MCL and Maximum Residual Disinfectant Levels (MRDL)

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with MCL/MRDL violations (Violations 02 and 11). The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mbdp/s1dbprimplguid.pdf> for additional information

#### Stage 1 DBPR M/R Violations

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with M/R violations (Violation 27 and Major Indicator Flag = Y). The contaminant codes for Stage 1 DBPR are 0400, 2920,

1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information

#### Public Notification

The violation code for failure to notify the public after a violation is 06 for IESWTR, LT1ESWTR, Stage 1 DBPR, . The contaminant code for Stage 1 DBPR corresponds with the appropriate MCL/MRDL/TOC (1009, 1011, 2456, 2950, 1006, 1008 and 0999). The contaminant code for IESWTR and LT1ESWTR is 0300. For FBRR the violation code is 75 and the contaminant code is 0500

# VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
01	MAXIMUM CONTAMINANT LEVEL (MCL), SINGLE SAMPLE	Exceedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITHOUT NUMBER OF EXCEEDANCE	Exceedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITH NUMBER OF EXCEEDANCE	Public Water Supply (PWS) Using Chlorine Dioxide - Chlorite - Average of any 3 sample set exceeds the MAXIMUM CONTAMINANT LEVEL (MCL) of 1.0 mg/L
03	MONITORING, ROUTINE MAJOR	Failure to monitor in accordance with section 5-1.51(b) and 5-1.52 Tables or perform analysis with approved methods
04	MONITORING, CONFIRMATION/CHECK MAJOR	No repeat samples were taken in reponse to a positive monitoring sample result.
07	TREATMENT TECHNIQUES NON-SURFACE WATER TREATMENT RULE (Non-SWTR)	Failure to maintain free chlorine residual in distribution system.
08	VARIANCE / EXEMPTION / OTHER COMPLIANCE	Failure to abide by the authorized terms and conditions of a valid variance, waiver, or any other exemption.
09	RECORD KEEPING	Failure to retain proper records.
09	RECORD KEEPING FOR INDIVIDUAL FILTER /Filter Backwash Rule (FBR)	Failure to maintain filter monitoring records for 3 years (filter results every 15 minutes)
11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) - Public Water Supply (PWS) Using Chlorine	Exceedence of Maximum Residual Disinfectant Level (MRDL) of 4.0 mg/L (exception if microbial contamination problems in distribution system)
11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) MONITORING	Failure to perform minimum monitoring requirements.
12	QUALIFIED OPERATOR FAILURE	No certified operator in charge of operation of a water treatment plant.
13	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) ACUTE - Public Water Supply (PWS) Using Chlorine Dioxide	ACUTE: If any of 3 required distribution samples taken on day after a daily entry point sample Maximum Residual Disinfectant Level (MRDL) exceeds 0.8 mg/L

# VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
21	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR) ACUTE	Exceedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6-- Microbiological Contaminants
22	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR), MONTHLY	Exceedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6-- Microbiological Contaminants
23	MONITORING TOTAL COLIFORM RULE (TCR), ROUTINE MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
25	MONITORING TOTAL COLIFORM RULE (TCR), REPEAT MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Bromate Monitoring / Reporting (M/R) - Public Water Supply (PWS) Using Ozone	Failure to collect 100% of required bromate samples
27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Chlorine Monitoring / Reporting (M/R)	Collecting <90% of chlorine samples
27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Total Organic Carbon (TOC) Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Using	Failure to collect source & finished water TOC samples and alkalinity sample
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM)-MAJOR Monitoring / Reporting (M/R) - SURFACE WATER / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000	Collecting <90% of (HAA5/TTHM) samples
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Population between 500 and 9999	Collecting <90% of (HAA5/TTHM) samples
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) < 500	Failure to collect/report at least 1 sample per plant per year during month of warmest water temperature
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems < 10,000 Population	Failure to collect/report all required samples

# VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
27	FAILURE TO HAVE MONITORING PLAN DISINFECTION BYPRODUCT RULE (DBP)	Failure to develop, implement or submit monitoring plan
29	FAILURE TO PRODUCE COMPREHENSIVE PERFORMANCE EVALUATION (CPE) - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to produce CPE evaluation documentation
31	MONITORING, ROUTINE/REPEAT - MAJOR - Surface Water Treatment Rule - UNFILTERED (SWTR - Unfiltered)	Failure to collect < 90% of require samples per monitoring period
36	MONITORING, Routine/Repeat MAJOR Surface Water Treatment Rule -FILTER	Failure to collect < 90% of require samples per monitoring period
37	FAILURE TO PROFILE / CONSULT - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to collect applicability data Treatment Technique (TT) violation
38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent Surface/Groundwater Under Direct Influence of Surface Water (GUDI) >= 10,000 Population with Conventional/Direct Filtration	Collecting <90% of filter effluent samples for turbidity and reporting within 10 days after end of month
38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Serving >= 10,000 Population with Conventional/Direct Filtration	Failure to report that Public Water Supply (PWS) has conducted all filter monitoring to state within 10 days after end of each month
41	RESIDUAL DISINFECT CONCENTRATION - Surface Water Treatment Rule (SWTR) Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI)) Serving Less Than 10,000	Cl <sub>2</sub> Residual fell below 0.2 mg/l for more than 4 hours.
41	SINGLE COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to maintain turbidity readings below 0.5 NTU in 95% of all measurements performed every 4 hours
41	MONTHLY COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to meet performance standard of 0.5 NTU at the 95th percentile monthly.
42	FAILURE TO FILTER (SWTR)	Failure to provide filtration on a surface source after 6/29/93, unless avoidance criteria is met.

# VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with	Failure to achieve turbidity <1.0 NTU, in 100% of samples
43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with	Failure to achieve turbidity <State set limit, in 100% of samples
44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with	Failure to achieve turbidity <0.3 NTU in 95% of samples
44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with	Failure to achieve turbidity <State set limit in 95% of samples
46	INADEQUATE DBP PRECURSOR REMOVAL - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) using conventional filtration	Failure to meet DBP precursor removal (TOC)
47	UNCOVERED STORAGE FACILITY - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Uncovered reservoir without adequate post disinfection.
51	INITIAL TAP SAMPLING (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42
52	FOLLOW-UP OR ROUTINE TAP Monitoring / Reporting (M/R) (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42
58	OPTIMAL CORROSION CONTROL TREATMENT / SOURCE WATER TREATMENT (OCCT/SOWT) INSTALLATION DEMONSTRATION	Failure to install and operate Optimal Corrosion Control Treatment (OCCT) or fail to demonstrate that OCCT already is in place.
65	PUBLIC EDUCATION LEAD / COPPER (PB/CU)	Failure to deliver public education materials where lead action level is exceeded.
71	CONSUMER CONFIDENCE REPORT (CCR)	Failure to provide Consumer Confidence Report
75	PUBLIC NOTICE RULE LINKED TO VIOLATION	Failure to Public Notice Violation of National Primary Drinking Water Regulations (NPDWR)